

# CCSD HIGH SCHOOL PROGRAM

# TABLE OF CONTENTS

|  |           |
|--|-----------|
| <b>Project Overview</b>  | <b>03</b> |
| Executive Summary  | 04        |
| Project Goals  | 05        |
| Participants   | 06        |
| <b>Program</b>   | <b>07</b> |
| Overall Program Blocks   | 08        |
| Program Blocks Breakout  | 09        |
| Program Matrix   | 12        |
| Program Summary  | 13        |
| Detailed Program   | 14        |
| Facility Considerations  | 24        |
| Room Data Sheets   | 29        |
| 01 Administrative Center                                       | 30        |
| 02 Fine and Performing Arts Center                             | 48        |
| 03 Physical Education Center                                   | 63        |
| 04 Student Activity Center /<br>Maintenance & Operation Center | 83        |
| 05 Arts Academy / Flex   | 95        |
| 06 Vocational Technologies<br>Learning Communities             | 102       |
| 09 Resource Material Center                                    | 107       |
| 10 Science Complex   | 115       |
|  | 121       |

# PROJECT

## OVERVIEW

# EXECUTIVE SUMMARY

The design team has had the pleasure of working with CCSD to develop a detailed program and updated high school ed spec for a new comprehensive high school.

The building will be 328,183 s.f. and will house typical high school functions and support spaces such as an administrative center, performing arts center, physical education center, student activity center, maintenance and operations center, arts center, resource media center, general science complex as well as general classrooms organized as four learning communities. It will also house space for potential career technical programs. The programs that will be offered in the school are not determined, but the design team is planning for multiple labs with various levels of infrastructure to allow for program flexibility.

During the programming phase, the 2000 CCSD High School Ed Spec was used as a guide, coupled with the design teams past experience with similar facilities and most importantly, the involvement of those in charge of running these departments in the district. An interactive programming process helped to align the existing building program from 2000 with the current space needs of 2023 as well as define the overarching goals of the project. Summaries and a detailed tabular program are provided within this document as are diagrams illustrating functional relationships and space specific requirements.

Refinement of the program has occurred over two workshops. Information gathering at each workshop was vital to keeping the design schedule on track, and there was excellent participation and follow through from all of the stakeholders. The information included in this document is the culmination of the efforts of all those involved.

Prior to the commencement of the programming workshops, the design team and CCSD visited Washoe County School District to tour two of their recently completed projects; Proctor R. Hug High School and O'Brien Middle School. We discussed the pros and cons of the existing space and which programs would be similar to those going into the new high school. We also spent time investigating their general use restrooms and discussed the positives and negatives of implementing them in the new CCSD high school. Based on these discussions, CCSD has decided to proceed with the general use restrooms which are reflected in the following programming documents.

The programming workshops were held in February and March of 2023. They began with a general overview and discussion of the overall goals for the new facility and included images from similar programs to facilitate the discussion of current trends and how the current CTA and commons spaces are used. After each session the design team used the information gathered to start a tabular program which identifies the spaces required for each department and began initial space layouts.

After the initial workshops were completed, we met with all stakeholders to review the information to date which included the initial layouts of each space. During this review the design team was able to gather the information needed to finalize the layout and size of the required spaces. We also discussed potential shared spaces, adjacencies, and verified each department's organization. Throughout the programming process, we met with CCSD Construction weekly to facilitate overall project progress.

## GUIDING STATEMENT + OBJECTIVES

The design will maximize the role of the built environment in achieving CCSD's goals and core values.



The design will provide innovative, flexible, and engaging spaces, foster intuitive teaching and learning, create a safe and welcoming environment for all, and reduce limitations to activating the facility.



The design will integrate spaces and programs, remove barriers to technology engagement, and allow for formal and informal settings for positive student academic and social activities.



The design will maximize flexibility and adaptability to champion meaningful learning now and into the future.



The design will thoughtfully engage parents/families as well as the greater community and support the continued strengthening of the many partnership relationships that influence student success.

# PARTICIPANTS

## Programming Participation Structure & Chain of Communication

### Executive Committee Members

Mark Campbell: CCSD | Interim Chief of Facilities  
Justin Lam : CCSD | Director, Construction Management  
Brandon McLaughlin: CCSD | Coordinator IV, Architecture  
Vincenzo Scalia : CCSD | Project Manager  
Melissa Avelar: CCSD | Project Manager  
Tracy Murphy : CCSD | Director, Demographics, Zoning, and GIS  
Victor Rodriguez: CCSD | Construction Management

### Departmental Participants

Sonia Houghton: ELL  
Lucas Leavitt: Online/blended Learning  
Kris Carroll: Science  
Chip Peterson: Health/PE  
Shannon La Neve: Humanities  
Jeffrey William: Fine Arts  
Robert Jones: Curriculum  
Jessica Lovell: Sierra Vista Principal  
Ian Salzman: Desert Oasis Principal  
Josh Chesnik: Facilities Management  
Kris Patrick: Food service  
Mitchell Maciszak: Police Services  
Jai Beasely: Emergency Management  
Paulette Marshall: Construction Management  
Gia Moore: Career Tech/Magnet  
Norman "Dean" Kiernan: Emergency Management  
Marelyn Lobo: Demographics, Zoning and GIS


### TSK + Huckabee

Kerri Brady  
Kevin Kemner  
Windom Kimsey  
Chris Lujan  
Jeni Panars  
Mike Purtill  
Mili Turnbull  
Wei Wu  
Edith Alvarez

# PROGRAM

## DIAGRAM BLOCKS

# OVERALL PROGRAM BLOCKS









# PROGRAM BLOCKS BREAKOUT

## 1.0 ADMINISTRATIVE CENTER


### 1.1 General Administrative Area




### 1.2 Dean's / Development Office Complex



### 1.3 Principal's Area





### 1.4 Health Services Area






## 2.0 FINE AND PERFORMING ARTS CENTER

### 2.1 Music Classrooms




### 2.2 Theater Complex




## 3.0 PHYSICAL EDUCATION CENTER


### 3.1 Athletic Administration Area




### 3.2 Gymnasium Area




### 3.3 Girl's Locker Area



### 3.5 Exercise, Weight, and Wrestling Rooms




### 3.6 Outside Rooms




## 4.0 STUDENT ACTIVITY CENTER / MAINTENANCE & OPERATIONS CENTER


### 4.1 Commons Area / Student Activity Center



### 4.2 Cafeteria Area




### 4.3 Maintenance & Operations Complex



## 5.0 CONSUMER SCIENCE CENTER / ARTS ACADEMY / LECTURE ROOM

### 5.1 Arts Center / Exterior Art Yard




### 5.2 Lecture Center




## 6.0 VOCATIONAL TECHNOLOGIES

### 6.1 CTE Program (Gia & Alaina)




## 7.0 LEARNING COMMUNITY - ONE

### 7.1 Administration




### 7.2 Classrooms, Computer / Business Lab



## 8.0 LEARNING COMMUNITY - TWO

### 8.1 Administration



### 8.2 Classrooms





## 9.0 RESOURCE MATERIAL CENTER

### 9.1 Library Center




## 10.0 SCIENCE COMPLEX

### 10.1 Science Classrooms



### 10.2 Science Teacher Prep / Office / Storage



### 10.3 Classrooms



## 11.0 LEARNING COMMUNITY - THREE

### 11.1 Administration



### 11.2 Classrooms




## 12.0 LEARNING COMMUNITY - FOUR

### 12.1 Administration



### 12.2 Classrooms




# PROGRAM

## PROGRAM MATRIX

# PROGRAM SUMMARY

| CCSD SOUTHWEST HIGH SCHOOL<br>PROGRAM SUMMARY                |                |
|--|----------------|
| 1   Administrative Center                                    | 10,715.00      |
| 2   Fine and Performing Arts Center                          | 21,190.00      |
| 3   Physical Education Center                                | 51,980.00      |
| 4   Student Activity Center/ Maintenance & Operations Center | 24,440.00      |
| 5   Arts Academy/ Flex                                       | 7,285.00       |
| 6   Vocational Technologies                                  | 22,930.00      |
| 7   Learning Community - One                                 | 16,100.00      |
| 8   Learning Community - Two                                 | 16,000.00      |
| 9   Resource Material  | 8,070.00       |
| 10   Science Complex   | 30,175.00      |
| 11   Learning Community - Three                              | 15,300.00      |
| 12   Learning Community - Four                               | 15,300.00      |
| Net Subtotal   | 239,485        |
| Circulation Factor (27%)                                     | 64,661         |
| Circulation Multiplier                                       | 1.37           |
| Circulation Area   | 88,698         |
| <b>BUILDING GROSS AREA TOTAL</b>                             | <b>328,183</b> |



# DETAILED PROGRAM

|            |                              |               |          |          |          |
|------------|------------------------------|---------------|----------|----------|----------|
| <b>1.0</b> | <b>ADMINISTRATIVE CENTER</b> | <b>10,715</b> | <b>0</b> | <b>0</b> | <b>0</b> |
|------------|------------------------------|---------------|----------|----------|----------|

| 1.1 | General Administrative Area                          | Qty. | Net Area | Total Net Area | Teaching<br>#T.S. | # Stud. | Capacity<br>@ 100% | Utilization % | Functional<br>Capacity |
|-----|--|------|----------|----------------|-------------------|---------|--------------------|---------------|------------------------|
| .01 | Reception Area                                       | 1    | 975      | 975            | 0                 |         | -                  |               | -                      |
| .02 | Registrar's Office                                   | 1    | 315      | 315            | 0                 |         | -                  |               | -                      |
|     | a. Record Vault                                      | 1    | 115      | 115            | 0                 |         | -                  |               | -                      |
| .03 | School Bank  | 1    | 165      | 165            | 0                 |         | -                  |               | -                      |
| .04 | Administrative/Student Personnel Copy Workroom       | 1    | 200      | 200            | 0                 |         | -                  |               | -                      |
|     | a. Supply/Storage Room                               | 1    | 270      | 270            | 0                 |         | -                  |               | -                      |
| .05 | E.R. Room  | 1    | 530      | 530            | 0                 |         | -                  |               | -                      |
|     | Office   | 1    | 120      | 120            | 0                 |         | -                  |               | -                      |
| .06 | Electrical Room                                      | 1    |          | 0              | 0                 |         | -                  |               | -                      |
| .07 | General Use Restrooms                                | 1    |          | 0              | 0                 |         | -                  |               | -                      |
| .08 | Office   | 2    | 120      | 240            | 0                 |         | -                  |               | -                      |
| .09 | Conference Room                                      | 1    | 425      | 425            | 0                 |         | -                  |               | -                      |
| .10 | Custodial Storage                                    | 1    | 50       | 50             | 0                 |         | -                  |               | -                      |
| .11 | Mail Room  | 1    | 200      | 200            | 0                 |         | -                  |               | -                      |
| .12 | Reprographics Room                                   | 1    | 470      | 470            | 0                 |         | -                  |               | -                      |
|     | a. Reprographics Room - Satellite                    | 2    | 120      | 240            | 0                 |         | -                  |               | -                      |
|     | b. Supply / Storage / Administrative / Reprographics | 1    | 595      | 595            | 0                 |         | -                  |               | -                      |
| .13 | Reception / Secretarial Office                       | 4    | 400      | 1,600          | 0                 |         | -                  |               | -                      |
|     | a. Storage Room                                      | 4    | 80       | 320            | 0                 |         | -                  |               | -                      |
|     |  |      |          | <b>6,830</b>   | <b>0</b>          |         | <b>0</b>           |               | <b>0</b>               |

| 1.2 | Dean's / Development Office Complex | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|-----|-------------------------------------|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01 | Reception Area                      | 1    | 655      | 655            | 0        |         | -        |               | -        |
| .02 | Office                              | 3    | 150      | 450            | 0        |         | -        |               | -        |
| .03 | Office                              | 3    | 120      | 360            | 0        |         | -        |               | -        |
|     |                                     |      |          | <b>1,465</b>   | <b>0</b> |         | <b>0</b> |               | <b>0</b> |

| 1.3 | Principal's Area | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|-----|------------------|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01 | Office           | 1    | 200      | 200            | 0        |         | -        |               | -        |
| .02 | Office           | 1    | 120      | 120            | 0        |         | -        |               | -        |
| .03 | Conference Room  | 1    | 425      | 425            | 0        |         | -        |               | -        |
| .04 | Office           | 5    | 150      | 750            | 0        |         | -        |               | -        |
|     |                  |      |          | <b>1,495</b>   | <b>0</b> |         | <b>0</b> |               | <b>0</b> |

| 1.4 | Health Services Area        | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|-----|-----------------------------|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01 | First Aid Workroom / Office | 1    | 375      | 375            | 0        |         | -        |               | -        |
| .02 | Restroom (Single-Occ)       | 2    |          | 0              | 0        |         | -        |               | -        |
| .03 | First Aid Cot Area          |      |          | -              | 0        |         | -        |               | -        |
|     | a. Well Room                | 1    | 175      | 175            | 0        |         | -        |               | -        |
|     | b. Sick Room                | 1    | 175      | 175            | 0        |         | -        |               | -        |
| .04 | T.R. Room                   | 1    | 200      | 200            | 0        |         | -        |               | -        |
|     |                             |      |          | <b>925</b>     | <b>0</b> |         | <b>0</b> |               | <b>0</b> |

# DETAILED PROGRAM

|            |  |               |          |            |            |
|------------|--|---------------|----------|------------|------------|
| <b>2.0</b> | <b>FINE AND PERFORMING ARTS CENTER</b> | <b>21,190</b> | <b>4</b> | <b>120</b> | <b>100</b> |
|------------|--|---------------|----------|------------|------------|

| <b>2.1 Music Classrooms</b> |                            | Qty. | Net Area | Total Net Area | Teaching #T.S. | # Stud. | Capacity @ 100% | Utilization % | Functional Capacity |
|-----------------------------|----------------------------|------|----------|----------------|----------------|---------|-----------------|---------------|---------------------|
| .01                         | Band Classroom             | 1    | 3,435    | 3,435          | 1              | 30      | 30              | 83%           | 25                  |
|                             | a. Music Department Office | 1    | 285      | 285            | 0              |         | -               |               | -                   |
|                             | b. Music Library           | 1    | 130      | 130            | 0              |         | -               |               | -                   |
|                             | c. Percussion Storage Room | 1    | 150      | 150            | 0              |         | -               |               | -                   |
|                             | d. Instrument Storage Room | 1    | 395      | 395            | 0              |         | -               |               | -                   |
|                             | e. Ensemble Room           | 1    | 205      | 205            | 0              |         | -               |               | -                   |
| .02                         | Orchestra Classroom        | 1    | 1,355    | 1,355          | 1              | 30      | 30              | 83%           | 25                  |
|                             | a. Instrument Storage Room | 1    | 325      | 325            | 0              |         | -               |               | -                   |
|                             | b. Practice Room           | 1    | 105      | 105            | 0              |         | -               |               | -                   |
| .03                         | Choral Classroom           | 1    | 1,540    | 1,540          | 1              | 30      | 30              | 83%           | 25                  |
|                             | a. Robe Storage Room       | 1    | 145      | 145            | 0              |         | -               |               | -                   |
|                             | b. Practice Room           | 1    | 105      | 105            | 0              |         | -               |               | -                   |
| .04                         | T.R. Room                  | 1    | 200      | 200            | 0              |         | -               |               | -                   |
|                             |                            |      |          | <b>8,375</b>   | <b>3</b>       |         | <b>90</b>       |               | <b>75</b>           |

| <b>2.2 Theater Complex</b> |                                   | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%    | Utilization % | Capacity  |
|----------------------------|-----------------------------------|------|----------|----------------|----------|---------|-----------|---------------|-----------|
| .01                        | Theater Lobby                     | 1    | 750      | 750            | 0        |         | -         |               | -         |
|                            | a. Theater Vestibule              | 1    | 250      | 250            | 0        |         | -         |               | -         |
|                            | b. General Use Restroom           | 1    |          | 0              | 0        |         | -         |               | -         |
|                            | c. Custodial Storage              | 1    | 65       | 65             | 0        |         | -         |               | -         |
| .02                        | Theater Seating                   | 1    | 5,270    | 5,270          | 0        |         | -         |               | -         |
| .03                        | Stage                             | 1    | 2,450    | 2,450          | 0        |         | -         |               | -         |
|                            | a. Vestibule                      | 1    | 125      | 125            | 0        |         | -         |               | -         |
| .04                        | Control Room                      | 1    | 705      | 705            | 0        |         | -         |               | -         |
| .05                        | Drama Classroom                   | 1    | 1,165    | 1,165          | 1        | 30      | 30        | 83%           | 25        |
|                            | a. Office                         | 1    | 120      | 120            | 0        |         | -         |               | -         |
|                            | b. Property Construction Storage  | 1    | 1,035    | 1,035          | 0        |         | -         |               | -         |
|                            | c. Prop Storage                   | 1    | 330      | 330            | 0        |         | -         |               | -         |
|                            | d. Exterior courtyard             | 1    |          | 0              | 0        |         | -         |               | -         |
|                            | e. Girl's Dressing / Waiting Room | 1    | 175      | 175            | 0        |         | -         |               | -         |
|                            | f. Girl's Performer's Restroom    | 1    |          | 0              | 0        |         | -         |               | -         |
|                            | g. Boy's Dressing / Waiting Room  | 1    | 175      | 175            | 0        |         | -         |               | -         |
|                            | h. Boy's Performer's Restroom     | 1    |          | 0              | 0        |         | -         |               | -         |
| .06                        | TR Room                           | 1    | 200      | 200            | 0        |         | -         |               | -         |
|                            |                                   |      |          | <b>12,815</b>  | <b>1</b> |         | <b>30</b> |               | <b>25</b> |

# DETAILED PROGRAM

|            |                                  |               |          |            |            |
|------------|----------------------------------|---------------|----------|------------|------------|
| <b>3.0</b> | <b>PHYSICAL EDUCATION CENTER</b> | <b>51,980</b> | <b>9</b> | <b>390</b> | <b>325</b> |
|------------|----------------------------------|---------------|----------|------------|------------|

| <b>3.1</b> | <b>Athletic Administration Area</b> | Qty. | Net Area | Total Net Area | Teaching<br>#T.S. | # Stud. | Capacity<br>@ 100% | Utilization % | Functional<br>Capacity |
|------------|-------------------------------------|------|----------|----------------|-------------------|---------|--------------------|---------------|------------------------|
| .01        | Athletic Director Office            | 1    | 120      | 120            | 0                 |         | -                  |               | -                      |
| .02        | Security/Police Campus Monitor      | 1    | 170      | 170            | 0                 |         | -                  |               | -                      |
|            |                                     |      |          | <b>290</b>     | <b>0</b>          |         | <b>0</b>           |               | <b>0</b>               |

| <b>3.2</b> | <b>Gymnasium Area</b>                         | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%     | Utilization % | Capacity   |
|------------|---|------|----------|----------------|----------|---------|------------|---------------|------------|
| .01        | Gymnasium Lobby                               | 1    | 1,995    | 1,995          | 0        |         | -          |               | -          |
|            | a. Concession Booth                           | 1    | 310      | 310            | 0        |         | -          |               | -          |
|            | b. Student Store                              | 1    | 230      | 230            | 0        |         | -          |               | -          |
|            | c. Storage Room                               | 1    | 80       | 80             | 0        |         | -          |               | -          |
|            | d. General Use Restroom                       | 1    |          | 0              | 0        |         | -          |               | -          |
| .02        | Gymnasium Floor (Size Midway between 18 & 15) | 1    | 19,425   | 19,425         | 4        | 50      | 200        | 83%           | 167        |
|            | a. Bleachers                                  | 1    |          | 0              | 0        |         | -          |               | -          |
| .03        | Women's Team Storage Room                     | 1    | 370      | 370            | 0        |         | -          |               | -          |
| .04        | Men's Team Storage Room                       | 1    | 370      | 370            | 0        |         | -          |               | -          |
| .05        | Performing Group Storage and Meeting Room     | 1    | 280      | 280            | 0        |         | -          |               | -          |
| .06        | Auxiliary Gymnasium                           | 1    | 6,930    | 6,930          | 2        | 50      | 100        | 83%           | 83         |
|            | a. Auxiliary Gymnasium Storage                | 1    | 270      | 270            | 0        |         | -          |               | -          |
| .07        | Custodial Storage Room                        | 1    | 150      | 150            | 0        |         | -          |               | -          |
| .08        | T.R. Room                                     | 1    | 200      | 200            | 0        |         | -          |               | -          |
| .09        | Equipment Storage (Football)                  | 1    | 420      | 420            | 0        |         | -          |               | -          |
|            |   |      |          | <b>31,030</b>  | <b>6</b> |         | <b>300</b> |               | <b>250</b> |

| <b>3.3</b> | <b>Girl's Locker Area</b>              | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|------------|--|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01        | Girl's Locker Area                     | 1    | 3,100    | 3,100          | 0        |         | -        |               | -        |
| .02        | Girl's Shower/Towelng Area             | 1    | 120      | 120            | 0        |         | -        |               | -        |
| .03        | Washer/Dryer Room                      | 1    | 140      | 140            | 0        |         | -        |               | -        |
| .04        | Girl's P.E. Restroom                   | 1    |          | 0              | 0        |         | -        |               | -        |
| .05        | Varsity Team Room/ First Aid Room      | 1    | 735      | 735            | 0        |         | -        |               | -        |
| .06        | Team Storage Rooms                     | 5    | 90       | 450            | 0        |         | -        |               | -        |
| .07        | Women's P.E. Staff Office              | 1    | 450      | 450            | 0        |         | -        |               | -        |
|            | a. Women's PE Staff Locker/Shower Room | 1    | 100      | 100            | 0        |         | -        |               | -        |
|            |  |      |          | <b>5,095</b>   | <b>0</b> |         | <b>0</b> |               | <b>0</b> |



# DETAILED PROGRAM

| <b>3.4 Boy's Locker Area</b> |                                      | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|------------------------------|--------------------------------------|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01                          | Boy's Locker Area                    | 1    | 3,100    | 3,100          | 0        |         | -        |               | -        |
| .02                          | Boy's Shower/Toweling Area           | 1    | 120      | 120            | 0        |         | -        |               | -        |
| .03                          | Washer/Dryer Room                    | 1    | 140      | 140            | 0        |         | -        |               | -        |
| .04                          | Boy's P.E. Restroom                  | 1    |          | 0              | 0        |         | -        |               | -        |
| .05                          | Varsity Team Room/ First Aid Room    | 1    | 735      | 735            | 0        |         | -        |               | -        |
| .06                          | Team Storage Rooms                   | 5    | 90       | 450            | 0        |         | -        |               | -        |
| .07                          | Men's P.E. Staff Office              | 1    | 450      | 450            | 0        |         | -        |               | -        |
|                              | a. Men's PE Staff Locker/Shower Room | 1    | 100      | 100            | 0        |         | -        |               | -        |
|                              |                                      |      |          | <b>5,095</b>   | <b>0</b> |         | <b>0</b> |               | <b>0</b> |

| <b>3.5 Exercise, Weight, and Wrestling Room</b> |   | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%    | Utilization % | Capacity  |
|---|---|------|----------|----------------|----------|---------|-----------|---------------|-----------|
| .01   | Exercise Room / Functional Fitness / Wellness | 2    | 1,705    | 3,410          | 2        | 30      | 60        | 83%           | 50        |
|   | a. Storage Room                               | 1    | 90       | 90             | 0        |         | -         |               | -         |
| .02   | Weight Room                                   | 1    | 2,100    | 2,100          | 1        | 30      | 30        | 83%           | 25        |
|   | a. Office                                     | 1    | 120      | 120            | 0        |         | -         |               | -         |
| .03   | Wrestling Room                                | 1    | 1,950    | 1,950          | 0        |         | -         |               | -         |
| .04   | Electrical Room                               | 1    |          | 0              | 0        |         | -         |               | -         |
| .05   | T.R. Room                                     | 2    | 200      | 400            | 0        |         | -         |               | -         |
|   |   |      |          | <b>8,070</b>   | <b>3</b> |         | <b>90</b> |               | <b>75</b> |

| <b>3.6 Outside Rooms</b> |                                   | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|--------------------------|-----------------------------------|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01                      | Ticket Booth                      | 0    | 0        | -              | 0        |         | -        |               | -        |
|                          | a. Concession Stand               | 1    | 600      | 600            | 0        |         | -        |               | -        |
|                          | b. Storage                        | 1    | 290      | 290            | 0        |         | -        |               | -        |
|                          | c. General Use Restroom           | 1    |          | 0              | 0        |         | -        |               | -        |
|                          | d. Custodial Storage              | 1    | 125      | 125            | 0        |         | -        |               | -        |
|                          | e. Turf Maintenance               | 1    | 600      | 600            | 0        |         | -        |               | -        |
| .02                      | Football/ Track Equipment Storage | 1    | 285      | 285            | 0        |         | -        |               | -        |
| .03                      | T.R. Room                         | 1    | 200      | 200            | 0        |         | -        |               | -        |
| .04                      | P.E./General Purpose Area         | 1    |          | 0              | 0        |         | -        |               | -        |
| .05                      | Football/Track                    | 1    |          | 0              | 0        |         | -        |               | -        |
| .06                      | Soccer Field                      | 1    |          | 0              | 0        |         | -        |               | -        |
| .07                      | Baseball Field                    | 1    |          | 0              | 0        |         | -        |               | -        |
| .08                      | Softball Field                    | 1    |          | 0              | 0        |         | -        |               | -        |
| .09                      | Concession Stand                  | 1    | 300      | 300            | 0        |         | -        |               | -        |
|                          | a. General Use Restroom           | 1    |          | 0              | 0        |         | -        |               | -        |
| .10                      | Basketball Courts                 | 6    |          | 0              | 0        |         | -        |               | -        |
| .11                      | Tennis Courts                     | 8    |          | 0              | 0        |         | -        |               | -        |
| .12                      | Future Portables (12 classrooms)  | 6    |          | 0              | 0        |         | -        |               | -        |
|                          |                                   |      |          | <b>2,400</b>   | <b>0</b> |         | <b>0</b> |               | <b>0</b> |

|            |  |               |          |          |          |
|------------|--|---------------|----------|----------|----------|
| <b>4.0</b> | <b>STUDENT ACTIVITY CENTER /<br/>MAINTENANCE &amp;<br/>OPERATIONS CENTER</b> | <b>24,440</b> | <b>0</b> | <b>0</b> | <b>0</b> |
|------------|--|---------------|----------|----------|----------|

| 4.1 | Commons Area / Student Activity Cen | Qty. | Net Area | Total Net Area | Teaching<br>#T.S. | # Stud. | Capacity<br>@ 100% | Utilization % | Functional<br>Capacity |
|-----|-------------------------------------|------|----------|----------------|-------------------|---------|--------------------|---------------|------------------------|
| .01 | Commons Area - Interior Plaza       | 1    | 6,755    | 6,755          | 0                 |         | -                  |               | -                      |
| .02 | Student Activity Center             | 1    | 8,140    | 8,140          | 0                 |         | -                  |               | -                      |
|     | a. Custodial Storage                | 1    | 100      | 100            | 0                 |         | -                  |               | -                      |
|     | b. Equipment Storage room           | 1    | 405      | 405            | 0                 |         | -                  |               | -                      |
| .03 | Student Government Room             | 1    | 250      | 250            | 0                 |         | -                  |               | -                      |
| .04 | TR Room                             | 1    | 200      | 200            | 0                 |         | -                  |               | -                      |
| .05 | Faculty Break Room                  | 1    | 700      | 700            | 0                 |         | -                  |               | -                      |
| .06 | Outside Patio Area                  | 1    |          | 0              | 0                 |         | -                  |               | -                      |
| .07 | Staff General Use Restroom          | 1    |          | 0              | 0                 |         | -                  |               | -                      |
|     |                                     |      |          | <b>16,550</b>  | <b>0</b>          |         | <b>0</b>           |               | <b>0</b>               |

| 4.2 | Cafeteria Area              | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|-----|-----------------------------|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01 | Food Serving Area           | 1    | 990      | 990            | 0        |         | -        |               | -        |
| .02 | Kitchen Prep Area           | 1    | 1,970    | 1,970          | 0        |         | -        |               | -        |
|     | a. Pot Washing              | 1    | 240      | 240            | 0        |         | -        |               | -        |
|     | b. Walk-in Refrigerator     | 1    | 260      | 260            | 0        |         | -        |               | -        |
|     | c. Walk-in Freezer          | 1    | 260      | 260            | 0        |         | -        |               | -        |
|     | d. General and Dry Storage  | 1    | 245      | 245            | 0        |         | -        |               | -        |
| .03 | Office                      | 1    | 120      | 120            | 0        |         | -        |               | -        |
| .04 | Cafeteria Staff Locker Room | 1    | 120      | 120            | 0        |         | -        |               | -        |
| .05 | Cafeteria Staff Restroom    | 1    |          | 0              | 0        |         | -        |               | -        |
|     |                             |      |          | <b>4,205</b>   | <b>0</b> |         | <b>0</b> |               | <b>0</b> |

| 4.3 | Maintenance & Operations Complex | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|-----|----------------------------------|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01 | General Workshop                 | 1    | 955      | 955            | 0        |         | -        |               | -        |
|     | a. Tool Storage Room             | 1    | 140      | 140            | 0        |         | -        |               | -        |
| .02 | Office                           | 1    | 120      | 120            | 0        |         | -        |               | -        |
|     | a. Staff Locker Area             | 1    | 60       | 60             | 0        |         | -        |               | -        |
|     | b. Staff General Use Restroom    | 1    |          | 0              | 0        |         | -        |               | -        |
| .03 | Main Electrical Room             | 1    | 420      | 420            | 0        |         | -        |               | -        |
| .04 | Emergency Electrical Room        | 1    | 70       | 70             | 0        |         | -        |               | -        |
| .05 | Boiler Room                      | 1    | 830      | 830            | 0        |         | -        |               | -        |
| .06 | Chiller Room                     | 1    | 1,090    | 1,090          | 0        |         | -        |               | -        |
| .07 | Mechanical Yard                  | 1    |          | 0              | 0        |         | -        |               | -        |
|     |                                  |      |          | <b>3,685</b>   | <b>0</b> |         | <b>0</b> |               | <b>0</b> |

# DETAILED PROGRAM

|            |                            |              |          |            |            |
|------------|----------------------------|--------------|----------|------------|------------|
| <b>5.0</b> | <b>ARTS ACADEMY / FLEX</b> | <b>7,285</b> | <b>4</b> | <b>120</b> | <b>100</b> |
|------------|----------------------------|--------------|----------|------------|------------|

| <b>5.1</b> | <b>Arts Center / Exterior Art Yard</b> | Qty. | Net Area | Total Net Area | Teaching<br>#T.S. | # Stud. | Capacity<br>@ 100% | Utilization % | Functional<br>Capacity |
|------------|--|------|----------|----------------|-------------------|---------|--------------------|---------------|------------------------|
| .01        | Art Classroom                          | 2    | 1,160    | 2,320          | 2                 | 30      | 60                 | 83%           | 50                     |
|            | a. Project Storage Rooms               | 1    | 290      | 290            | 0                 |         | -                  |               | -                      |
| .02        | Ceramics                               | 1    | 1,160    | 1,160          | 1                 | 30      | 30                 | 83%           | 25                     |
|            | a. Project Storage Rooms               | 1    | 335      | 335            | 0                 |         | -                  |               | -                      |
|            | b. Slip Room                           | 1    | 155      | 155            | 0                 |         | -                  |               | -                      |
|            | c. Kiln Room                           | 1    | 125      | 125            | 0                 |         | -                  |               | -                      |
|            | d. Art Yard                            | 1    |          | 0              | 0                 |         | -                  |               | -                      |
| .03        | Electrical/Mechanical Room             | 1    |          | 0              | 0                 |         | -                  |               | -                      |
|            |  |      |          | <b>4,385</b>   | <b>3</b>          |         | <b>90</b>          |               | <b>75</b>              |

| <b>5.2</b> | <b>Flex Room</b> | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%    | Utilization % | Capacity  |
|------------|------------------|------|----------|----------------|----------|---------|-----------|---------------|-----------|
| .01        | Flex Room        | 1    | 2,700    | 2,700          | 1        | 30      | 30        | 83%           | 25        |
|            |                  |      |          | <b>2,700</b>   | <b>1</b> |         | <b>30</b> |               | <b>25</b> |

|            |                                |               |           |            |            |
|------------|--------------------------------|---------------|-----------|------------|------------|
| <b>6.0</b> | <b>VOCATIONAL TECHNOLOGIES</b> | <b>22,930</b> | <b>11</b> | <b>330</b> | <b>275</b> |
|------------|--------------------------------|---------------|-----------|------------|------------|

| <b>6.1</b> | <b>CTE Program</b>      | Qty. | Net Area | Total Net Area | Teaching<br>#T.S. | # Stud. | Capacity<br>@ 100% | Utilization % | Functional<br>Capacity |
|------------|-------------------------|------|----------|----------------|-------------------|---------|--------------------|---------------|------------------------|
| .01        | CTE lab Type A          | 3    | 1,350    | 4,050          | 3                 | 30      | 90                 | 83%           | 75                     |
| .02        | CTE lab Type B          | 6    | 1,800    | 10,800         | 6                 | 30      | 180                | 83%           | 150                    |
| .03        | CTE lab Type C          | 2    | 3,600    | 7,200          | 2                 | 30      | 60                 | 83%           | 50                     |
| .04        | Distributed lab storage | 3    | 160      | 480            | 0                 |         | -                  |               | -                      |
| .05        | T.R. Room               | 2    | 200      | 400            | 0                 |         | -                  |               | -                      |
|            |                         |      |          | <b>22,930</b>  | <b>11</b>         |         | <b>330</b>         |               | <b>275</b>             |

# DETAILED PROGRAM

|            |                                 |               |           |            |            |
|------------|---------------------------------|---------------|-----------|------------|------------|
| <b>7.0</b> | <b>LEARNING COMMUNITY - ONE</b> | <b>16,100</b> | <b>16</b> | <b>441</b> | <b>368</b> |
|------------|---------------------------------|---------------|-----------|------------|------------|

| <b>7.1</b> | <b>Administration</b>      | Qty. | Net Area | Total Net Area | Teaching<br>#T.S. | # Stud. | Capacity<br>@ 100% | Utilization % | Functional<br>Capacity |
|------------|----------------------------|------|----------|----------------|-------------------|---------|--------------------|---------------|------------------------|
| .01        | Office                     | 2    | 120      | 240            | 0                 |         | -                  |               | -                      |
| .02        | Staff General Use Restroom | 1    |          | 0              | 0                 |         | -                  |               | -                      |
| .03        | Electrical Room            | 1    |          | 0              | 0                 |         | -                  |               | -                      |
| .04        | Teacher's Workroom         | 1    | 400      | 400            | 0                 |         | -                  |               | -                      |
| .05        | Conference Room            | 1    | 300      | 300            | 0                 |         | -                  |               | -                      |
|            |                            |      |          | <b>940</b>     | <b>0</b>          |         | <b>0</b>           |               | <b>0</b>               |

| <b>7.2</b> | <b>Classrooms</b>            | Qty. | Net Area | Total Net Area | #T.S.     | # Stud. | @ 100%     | Utilization % | Capacity   |
|------------|------------------------------|------|----------|----------------|-----------|---------|------------|---------------|------------|
| .01        | Generic Classroom            | 13   | 900      | 11,700         | 13        | 30      | 390        | 83%           | 325        |
| .02        | Flex Lab / Classroom         | 1    | 1,800    | 1,800          | 1         | 30      | 30         | 83%           | 25         |
| .03        | Resource Classroom           | 1    | 600      | 600            | 1         | 12      | 12         | 83%           | 10         |
| .04        | Self-Contained               | 1    | 900      | 900            | 1         | 9       | 9          | 83%           | 8          |
|            | a. Restroom                  | 1    |          | 0              | 0         |         | -          |               | -          |
|            | b. Storage                   | 1    | 60       | 60             | 0         |         | -          |               | -          |
| .05        | Student General Use Restroom | 1    |          | 0              | 0         |         | -          |               | -          |
| .06        | Custodial Storage Room       | 1    | 100      | 100            | 0         |         | -          |               | -          |
| .07        | Fire Riser Room              | 1    |          | 0              | 0         |         | -          |               | -          |
|            |                              |      |          | <b>15,160</b>  | <b>16</b> |         | <b>441</b> |               | <b>368</b> |

|            |                                 |               |           |            |            |
|------------|---------------------------------|---------------|-----------|------------|------------|
| <b>8.0</b> | <b>LEARNING COMMUNITY - TWO</b> | <b>16,000</b> | <b>16</b> | <b>441</b> | <b>368</b> |
|------------|---------------------------------|---------------|-----------|------------|------------|

| <b>8.1</b> | <b>Administration</b> | Qty. | Net Area | Total Net Area | Teaching<br>#T.S. | # Stud. | Capacity<br>@ 100% | Utilization % | Functional<br>Capacity |
|------------|-----------------------|------|----------|----------------|-------------------|---------|--------------------|---------------|------------------------|
| .01        | Office                | 2    | 120      | 240            | 0                 |         | -                  |               | -                      |
| .02        | Staff Restroom        | 1    |          | 0              | 0                 |         | -                  |               | -                      |
| .03        | Electrical Room       | 1    |          | 0              | 0                 |         | -                  |               | -                      |
| .04        | Teacher's Workroom    | 1    | 400      | 400            | 0                 |         | -                  |               | -                      |
| .05        | Conference Room       | 1    | 300      | 300            | 0                 |         | -                  |               | -                      |
|            |                       |      |          | <b>940</b>     | <b>0</b>          |         | <b>0</b>           |               | <b>0</b>               |

| <b>8.2</b> | <b>Classrooms</b>     | Qty. | Net Area | Total Net Area | #T.S.     | # Stud. | @ 100%     | Utilization % | Capacity   |
|------------|-----------------------|------|----------|----------------|-----------|---------|------------|---------------|------------|
| .01        | Generic Classroom     | 13   | 900      | 11,700         | 13        | 30      | 390        | 83%           | 325        |
| .02        | Flex Lab / Classroom  | 1    | 1,800    | 1,800          | 1         | 30      | 30         | 83%           | 25         |
| .03        | Resource Classroom    | 1    | 600      | 600            | 1         | 12      | 12         | 83%           | 10         |
| .04        | Self-Contained        | 1    | 900      | 900            | 1         | 9       | 9          | 83%           | 8          |
|            | a. Restroom           | 1    |          | 0              | 0         |         | -          |               | -          |
|            | b. Storage            | 1    | 60       | 60             | 0         |         | -          |               | -          |
| .05        | Student Restroom      | 1    |          | 0              | 0         |         | -          |               | -          |
| .06        | Elevator Machine Room | 1    |          | 0              | 0         |         | -          |               | -          |
| .07        | Elevators             | 2    |          | 0              | 0         |         | -          |               | -          |
|            |                       |      |          | <b>15,060</b>  | <b>16</b> |         | <b>441</b> |               | <b>368</b> |

# DETAILED PROGRAM

|            |                                 |              |          |           |           |
|------------|---------------------------------|--------------|----------|-----------|-----------|
| <b>9.0</b> | <b>RESOURCE MATERIAL CENTER</b> | <b>8,070</b> | <b>1</b> | <b>30</b> | <b>25</b> |
|------------|---------------------------------|--------------|----------|-----------|-----------|

| <b>9.1 Library Center</b> |   | Qty. | Net Area | Total Net Area | Teaching #T.S. | # Stud. | Capacity @ 100% | Utilization % | Functional Capacity |
|---------------------------|---|------|----------|----------------|----------------|---------|-----------------|---------------|---------------------|
| .01                       | Collaboration Space                       | 1    | 2,450    | 2,450          | 0              |         | -               |               | -                   |
| .02                       | Book Stacks                               | 1    | 2,150    | 2,150          | 0              |         | -               |               | -                   |
| .03                       | Small Group Rooms                         | 4    | 135      | 540            | 0              |         | -               |               | -                   |
| .04                       | Office                                    | 1    | 165      | 165            | 0              |         | -               |               | -                   |
| .05                       | Site-Based Technician                     | 1    | 600      | 600            | 0              |         | -               |               | -                   |
| .06                       | Library Conference/Career Counseling Room | 1    | 585      | 585            | 0              |         | -               |               | -                   |
| .07                       | Research/Career Classroom                 | 1    | 900      | 900            | 1              | 30      | 30              | 83%           | 25                  |
| .08                       | Library Storage/ Workroom                 | 1    | 680      | 680            | 0              |         | -               |               | -                   |
|                           |   |      |          | <b>8,070</b>   | <b>1</b>       |         | <b>30</b>       |               | <b>25</b>           |

|             |                        |               |           |            |            |
|-------------|------------------------|---------------|-----------|------------|------------|
| <b>10.0</b> | <b>SCIENCE COMPLEX</b> | <b>30,175</b> | <b>20</b> | <b>582</b> | <b>485</b> |
|-------------|------------------------|---------------|-----------|------------|------------|

| <b>10.1 Science Classrooms</b> |   | Qty. | Net Area | Total Net Area | Teaching #T.S. | # Stud. | Capacity @ 100% | Utilization % | Functional Capacity |
|--------------------------------|---|------|----------|----------------|----------------|---------|-----------------|---------------|---------------------|
| .01                            | General Science Laboratory / Classrooms | 15   | 1,385    | 20,775         | 15             | 30      | 450             | 83%           | 375                 |
| .02                            | Chemistry Laboratory / Classrooms       | 4    | 1,385    | 5,540          | 4              | 30      | 120             | 83%           | 100                 |
|                                |   |      |          | <b>26,315</b>  | <b>19</b>      |         | <b>570</b>      |               | <b>475</b>          |

| <b>10.2 Science Teacher Prep / Office / Storage</b> |                                      | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|---|--------------------------------------|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01   | Science Teacher Prep/ Office Area    | 1    | 850      | 850            | 0        |         | -        |               | -        |
|   | a. Science Teacher Prep Storage Room | 1    | 185      | 185            | 0        |         | -        |               | -        |
|   | b. Physics / Chemistry Storage Room  | 1    | 165      | 165            | 0        |         | -        |               | -        |
|   | c. Science Text Book Storage Room    | 1    | 165      | 165            | 0        |         | -        |               | -        |
| .02   | Staff General Use Restroom           | 1    |          | 0              | 0        |         | -        |               | -        |
| .03   | Custodial Storage                    | 1    | 55       | 55             | 0        |         | -        |               | -        |
| .04   | Electrical / Mechanical Room         | 1    |          | 0              | 0        |         | -        |               | -        |
| .05   | T.R. Room                            | 2    | 200      | 400            | 0        |         | -        |               | -        |
| .06   | Riser Room                           | 1    |          | 0              | 0        |         | -        |               | -        |
| .07   | Student Restroom                     | 1    |          | 0              | 0        |         | -        |               | -        |
|   |                                      |      |          | <b>1,820</b>   | <b>0</b> |         | <b>0</b> |               | <b>0</b> |

| <b>10.3 Classrooms</b> |                     | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%    | Utilization % | Capacity  |
|------------------------|---------------------|------|----------|----------------|----------|---------|-----------|---------------|-----------|
| .01                    | Resource Classroom  | 1    | 600      | 600            | 1        | 12      | 12        | 83%           | 10        |
| .02                    | Journalism Workroom | 1    | 600      | 600            | 0        |         | -         |               | -         |
|                        | a. Storage Room     | 1    | 120      | 120            | 0        |         | -         |               | -         |
| .03                    | Yearbook Workroom   | 1    | 600      | 600            | 0        |         | -         |               | -         |
|                        | a. Storage Room     | 1    | 120      | 120            | 0        |         | -         |               | -         |
|                        |                     |      |          | <b>2,040</b>   | <b>1</b> |         | <b>12</b> |               | <b>10</b> |

# DETAILED PROGRAM

| <b>11.0 LEARNING COMMUNITY - THREE</b> |                        | <b>15,300</b> | <b>15</b> | <b>393</b>     | <b>328</b>     |         |                 |               |                     |
|--|------------------------|---------------|-----------|----------------|----------------|---------|-----------------|---------------|---------------------|
| <b>11.1</b>                            | <b>Administration</b>  | Qty.          | Net Area  | Total Net Area | Teaching #T.S. | # Stud. | Capacity @ 100% | Utilization % | Functional Capacity |
| .01                                    | Office                 | 2             | 120       | 240            | 0              |         | -               |               | -                   |
| .02                                    | Staff Restroom         | 1             |           | 0              | 0              |         | -               |               | -                   |
| .03                                    | Electrical Room        | 1             |           | 0              | 0              |         | -               |               | -                   |
| .04                                    | T.R. Room              | 2             | 200       | 400            | 0              |         | -               |               | -                   |
| .05                                    | Teacher's Workroom     | 1             | 400       | 400            | 0              |         | -               |               | -                   |
| .06                                    | Conference Room        | 1             | 300       | 300            | 0              |         | -               |               | -                   |
|  |                        |               |           | <b>1,340</b>   | <b>0</b>       |         | <b>0</b>        |               | <b>0</b>            |
| <b>11.2</b>                            | <b>Classrooms</b>      | Qty.          | Net Area  | Total Net Area | #T.S.          | # Stud. | @ 100%          | Utilization % | Capacity            |
| .01                                    | Generic Classroom      | 11            | 900       | 9,900          | 11             | 30      | 330             | 83%           | 275                 |
| .02                                    | Flex Lab / Classroom   | 1             | 1,800     | 1,800          | 1              | 30      | 30              | 83%           | 25                  |
| .03                                    | Resource Classroom     | 2             | 600       | 1,200          | 2              | 12      | 24              | 83%           | 20                  |
| .04                                    | Self-Contained         | 1             | 900       | 900            | 1              | 9       | 9               | 83%           | 8                   |
|  | a. Restroom            | 1             |           | 0              | 0              |         | -               |               | -                   |
|  | b. Storage             | 1             | 60        | 60             | 0              |         | -               |               | -                   |
| .05                                    | Student Restroom       | 1             |           | 0              | 0              |         | -               |               | -                   |
| .06                                    | Custodial Storage Room | 1             | 100       | 100            | 0              |         | -               |               | -                   |
| .07                                    | Fire Riser Room        | 1             |           | 0              | 0              |         | -               |               | -                   |
|  |                        |               |           | <b>13,960</b>  | <b>15</b>      |         | <b>393</b>      |               | <b>328</b>          |

# DETAILED PROGRAM

| <b>12.0 LEARNING COMMUNITY - FOUR</b> |      | <b>15,300</b> |                | <b>15</b>      |         | <b>393</b>      |               | <b>328</b>          |  |
|---------------------------------------|------|---------------|----------------|----------------|---------|-----------------|---------------|---------------------|--|
| <b>12.1 Administration</b>            | Qty. | Net Area      | Total Net Area | Teaching #T.S. | # Stud. | Capacity @ 100% | Utilization % | Functional Capacity |  |
| .01 Office                            | 2    | 120           | 240            | 0              |         | -               |               | -                   |  |
| .02 Staff Restroom                    | 1    |               | 0              | 0              |         | -               |               | -                   |  |
| .03 Electrical Room                   | 1    |               | 0              | 0              |         | -               |               | -                   |  |
| .04 T.R. Room                         | 2    | 200           | 400            | 0              |         | -               |               | -                   |  |
| .05 Teacher's Workroom                | 1    | 400           | 400            | 0              |         | -               |               | -                   |  |
| .06 Conference Room                   | 1    | 300           | 300            | 0              |         | -               |               | -                   |  |
|                                       |      |               | <b>1,340</b>   | <b>0</b>       |         | <b>0</b>        |               | <b>0</b>            |  |
| <b>12.2 Classrooms</b>                | Qty. | Net Area      | Total Net Area | #T.S.          | # Stud. | @ 100%          | Utilization % | Capacity            |  |
| .01 Generic Classroom                 | 11   | 900           | 9,900          | 11             | 30      | 330             | 83%           | 275                 |  |
| .02 Flex Lab / Classroom              | 1    | 1,800         | 1,800          | 1              | 30      | 30              | 83%           | 25                  |  |
| .03 Resource Classroom                | 2    | 600           | 1,200          | 2              | 12      | 24              | 83%           | 20                  |  |
| .04 Self-Contained                    | 1    | 900           | 900            | 1              | 9       | 9               | 83%           | 8                   |  |
| a. Restroom                           | 1    |               | 0              | 0              |         | -               |               | -                   |  |
| b. Storage                            | 1    | 60            | 60             | 0              |         | -               |               | -                   |  |
| .05 Student Restroom                  | 1    |               | 0              | 0              |         | -               |               | -                   |  |
| .06 Custodial Storage Room            | 1    | 100           | 100            | 0              |         | -               |               | -                   |  |
| .07 Elevators                         | 2    |               | 0              | 0              |         | -               |               | -                   |  |
|                                       |      |               | <b>13,960</b>  | <b>15</b>      |         | <b>393</b>      |               | <b>328</b>          |  |

# PROGRAM

## **FACILITY CONSIDERATIONS**



# FACILITY CONSIDERATIONS

## Facility Considerations | Interior Areas

1. 2,700 student capacity.
2. 111 teaching stations.
3. Provide individual classroom lighting controls at all entrance / exit doors to darken classrooms for presentations and provide switching for emergency lighting tied to the security system.
4. Provide individual classroom HVAC zoning.
5. Provide an Energy Management System with 15% expansion capability as directed by the CCSD Energy Manager. System should allow control from both the school maintenance center and the centralized school district Energy Management Control Center.
6. Any interior school area that will accommodate 50 or more persons in an assembly, should be provided with assistive listening devices, equivalent to the infrared ALS system.
7. Speaker strobe fire alarm device in all classrooms, library, commons, gymnasium, and all other areas as required by code. Locate in standard visible areas for all classrooms.
8. Provide signs for an interior signage package to consist of (1) room number(s) and room usage signage to meet the requirements of Section 504 of the Federal Rehabilitation Act, ANSI Act 117.1 (2003) and U.S. Public Law 92-112 (1986); and (2) directional signage to indicate location(s) of rooms coming from the office and “to office” signs from the exterior doors back to the office. Signage should meet ADA and requirements and CCSD standards.
9. All office or classroom windows facing the exterior should receive interior roller shades. The Health Room windows should receive interior one-touch horizontal blinds.
10. Provide IP based master clock / intercom system.
11. Provide necessary wiring infrastructure for voice over IP phone service that meets CCSD networking service standards.
12. Fire extinguisher cabinets should be recessed except in locations that are concrete or concrete masonry walls, where the cabinets are to be surface mounted.
13. Do NOT install fire alarm pull stations next to exterior exit doors.
14. Provide a CCTV System (surveillance cameras) for hallways, interior courtyard, bus loading, basketball and tennis courts, field areas, entrance gates, and otherwise directed by CCSD police services.
15. Ensure that any wall hung lavatories, toilet carriers, and associated cabinetry receive additional support. i.e. backing from pulling away from the wall.
16. Do NOT provide paper towel dispensers in any rest rooms.
17. Mop sinks adjacent to sheet rock / furred walls should have a FRP to wainscot height on the two adjacent walls (surrounding the mop sink).
18. A/E and Consultants must ensure coordination with other disciplines, i.e.; consider location of items such as tackboards, coat racks and their adjacency to sinks, doors, power/data receptacles, fire alarm devices, etc.
19. All interior drinking fountains and electric water coolers should have resilient tile floor under the wall-mounted unit a minimum of 2 feet out from the wall. Provide wall behind fountain or cooler with ceramic tile wainscot.
20. Student drinking fountains should not be electric water coolers. Provide ADA compliant model design that minimizes spillage over the edge.
21. All electrical receptacles within 6 feet of water should be GFIC (Ground Fault Interrupt Connection).
22. All rest room should be vented to the outside.
23. Provide trap primer at floor drains.
24. Provide tempered water for all rest room sinks and other areas as specified in this document and as required by SNHD.
25. The bottom of wall-mounted writing surfaces and tackboards are 3' 0" A.F.F. to bottom of the marker rail unless otherwise indicated. (Locate 3' 7" A.F.F. above plug-mold, counters, and library bookcases.)
26. All hallway floors should be VCT.
27. Provide kick plates on all doors.

# FACILITY CONSIDERATIONS

28. Do NOT place any electrical equipment or electrical room adjacent to the ER Room (Equipment Room) or TR (telecom room) locations.

29. Security Keypad should be located in the following areas:

- a. Reception by the Principal's Office
- b. Entrance door into the Faculty Dining Area
- c. Kitchen Receiving Area
- d. Security Office Area
- e. Data / Telecom / IDF Room
- f. Theater Custodial Room
- g. Library Workroom

30. Provide a separate roof antenna, conduit and roof support for ITV / CTV systems. Provide conduit, roof penetration and satellite dish support at the roof near the, ER (Equipment Room).

31. Provide an ER (Equipment Room) in a central location within the facility. This room shall support the following systems: Data, ITV / CTV, telecommunications, clock / intercom, EMS, fire system, and UPS. Size the room and provide cabinets(s) / racks(s) quantities as required by CCSD - Networking Services.

- a. The ER (Equipment Room) shall be maintained at 74 degrees Fahrenheit year round.
- b. The ER (Equipment Room) electrical power shall be supported by UPS Tied into the site life / safety backup generator.
- c. Provide data wiring infrastructure.
- d. Provide electrical power within the ER (Equipment Room) to support all required equipment /infrastructure.

32. Provide TR Room(s) as needed to limit the length of copper data cabling (less than 150 feet). Size the room(s) and provide cabinet(s) / rack(s) quantities as required by CCSD - Networking Services.

- a. Provide backboard within the TR Room for telephone, ITV / CTV and security wiring.
- b. Provide electrical power within the TR Room for the ITV / CTV system and for each cabinet / rack to be installed.
- c. Provide ladder tray for cable management within the TR Room above the cabinet / rack and below the ceiling line.

33. (4) 4" conduits and (1) 2" conduit between ER and TRs.

34. In the ER (Equipment Room) and each TR Room, ensure that each cabinet / rack and ladder tray are properly grounded.

35. For the latest CCSD conduit, cable and wiring methods for data, telephone, ITV / CTV, and clock / intercom / security (CIS) wiring, please review specifications with CCSD - Networking Services.

36. Provide one duplex electrical outlet adjacent to each individual data port.

37. Acoustic guidelines for areas with special sound attenuation needs.

a. Common's area should accommodate a wide range of functions with various acoustic requirements.

- i. Provide a balanced reverberation time (or utilize adjustable absorption) to accommodate intended use functions.
- ii. Provide moderate to high levels of sound isolation.
- iii. Distribute sound absorptive wall treatment throughout the room.
- iv. Mitigate background (ambient) sound levels from HVAC equipment and air distribution system to accommodate the acoustic criteria for the most stringent use function.

b. Conference rooms and some offices should maximize sound isolation to accommodate confidential conferences.

- i. Provide a high degree of sound isolation (STC approximately 50+) at walls and floor / ceiling construction.
- ii. Provide moderately absorptive ceiling and wall treatment.

c. Theater should maximize speech intelligibility and sound isolation.

- i. Splay ceiling and side walls at the front of the room.
- ii. Provide sound absorbing rear wall treatment.
- iii. Mitigate reverberation for a balanced acoustic quality live enough to promote sound projection; dead enough to avoid unwanted reflections.
- iv. Provide a high degree of sound isolation (STC approximately 50+) at walls and floor / ceiling construction.
- v. Mitigate background (ambient) sound levels from HVAC equipment and air distribution system.
- vi. Provide gasketed doors or sound isolating doors or vestibules.

d. Music rooms should maximize sound isolation for non-disturbance of nearby classrooms. Chorus room ceiling needs to be high enough to accommodate three-tier risers.

- i. Mitigate reverberation for a balanced acoustic quality live enough to promote sound projection; dead enough to avoid unwanted reflections.
- ii. Provide a high degree of sound isolation at walls and floor / ceiling construction (sound transmission class may not be applicable due to low-frequency noise).
- iii. Mitigate background (ambient) sound levels from HVAC equipment and air distribution systems.
- iv. Provide gasketed doors or sound isolating doors or vestibules.

# FACILITY CONSIDERATIONS

- e. Noisy rooms such as reprographics room, ER (Equipment Room), workrooms, art room, and mechanical equipment rooms should reduce interior sound levels and maximize sound isolation.
  - i. Provide sound absorptive ceiling and wall treatment.
  - ii. Provide a high degree of sound isolation at walls and floor / ceiling construction (sound transmission class may not be applicable due to low-frequency noise).
  - iii. Mitigate background (ambient) sound levels from HVAC equipment and air distribution systems.
  - iv. Provide gasketed doors or sound isolating doors or vestibules.
- f. Classrooms should minimize sound transmission from nearby classrooms.
- g. Library should minimize sound transmission from nearby classrooms.
  - i. Distribute sound absorptive wall treatment throughout the room walls and ceiling.
- h. Lecture Rooms
  - i. Provide a high degree of sound isolation (STC approximately 50+) at walls and floor / ceiling construction.
  - ii. Provide moderately absorptive ceiling and wall treatment.
  - iii. Mitigate background (ambient) sound levels from the HVAC equipment and air distribution systems.

**38. Semi-gloss paint must be provided for finish surfaces throughout.**

**39. Interior doors to offices, classrooms, library, etc., should have observation windows 8 inches wide by 3 feet long as a minimum unless otherwise indicated.**

**40. Provide small HVAC package unit with emergency power circuit for emergency electrical room.**

**41. To reduce the maintenance and vandalism on exterior doors, the Clark County School District Maintenance Department has requested that geared continuous hinges be used on high use exterior doors. This will include all doors except mechanical rooms, boiler rooms, electrical rooms, and storage rooms, etc.**

**42. Flush door pulls are to be used on the exterior of mechanical rooms, boiler rooms, electrical rooms, and storage rooms, etc.**

# FACILITY CONSIDERATIONS

## Facility Considerations | Exterior Areas

1. Provide school name and street address in metal lettering located at the front of the school high upon the wall and easily visible from the street. Street address numbers should also be located on the roof.
2. Provide a flagpole and dedication plaque located at the front of the school in a visible location.
3. Provide school bus loading / unloading for (23) buses minimum.
4. Provide faculty, student, and visitor parking to meet the code minimum requirements per jurisdiction.
5. Paint appropriate curb red and mark as “No Parking - Fire Lane.”
6. Provide lighting in all parking and bus areas.
7. Provide a (10) bike-rack enclosure. (Approximately 1,600 square feet, 20 bicycles per rack, inside an 8 foot fence.) Install gates for accesses.
8. Place vandal-resistant hose bibs on each side of the building and courtyard for wash down of areas. Place vandal-resistant quick coupler valves in outlying areas where flexibility is needed and a hose bib may be inappropriate.
9. Ensure external speakers (for communication from the office) in the interior courtyard area and one external speaker on each exterior side of building towards the basketball and tennis courts and fields to enable students to hear school alarms, recalls, and messages.
10. Electrical, fire alarm, intercom, and data and ITV / CTV conduit connections for siting (12) future portable classrooms (6 portables). Portables should be sited to face the school, therefore, stub-up and pull boxes for connections should be as per CCSD Construction Management and Maintenance current specifications.
11. All fencing to be galvanized. No vinyl coated fencing.
12. Ensure any exterior area that can be used for hiding to be fenced off.
13. Any external, appurtenances should not be accessible to enable students to climb up to the roof.
14. Exterior roof drain down spouts should be located away from exterior doorways.
15. Provide 32 foot wide gate for future portable classrooms mobile access from the street near portable location on site.
16. Provide water isolation valves for separate building areas.
17. Provide gated trash enclosure area for six dumpsters with automatic night controlled lighting and a hose bib for area wash down.
18. Provide power type can wash near the dumpsters.
19. Provide exterior drinking fountains with at least (3) bubblers on all sides of the building and courtyard. Include vandal-resistant hose bib under the fountains.
20. Fire hydrants should not be located in the asphalt or field turf areas.
21. Courtyard planters should be raised to sitting height approximately 24 inches A.F.F. as a minimum.
22. Verify conformance with noise protection requirements as applicable, (i.e. airport traffic area).

# PROGRAM

## ROOM DATA SHEETS

# 01 ADMINISTRATIVE CENTER

# ADMINISTRATIVE CENTER


|            |                              |               |          |          |          |
|------------|------------------------------|---------------|----------|----------|----------|
| <b>1.0</b> | <b>ADMINISTRATIVE CENTER</b> | <b>10,715</b> | <b>0</b> | <b>0</b> | <b>0</b> |
|------------|------------------------------|---------------|----------|----------|----------|

|            |  | Qty. | Net Area | Total Net Area | Teaching<br>#T.S. | # Stud. | Capacity<br>@ 100% | Utilization % | Functional<br>Capacity |
|------------|--|------|----------|----------------|-------------------|---------|--------------------|---------------|------------------------|
| <b>1.1</b> | <b>General Administrative Area</b>                   |      |          |                |                   |         |                    |               |                        |
| .01        | Reception Area                                       | 1    | 975      | 975            | 0                 |         | -                  |               | -                      |
| .02        | Registrar's Office                                   | 1    | 315      | 315            | 0                 |         | -                  |               | -                      |
|            | a. Record Vault                                      | 1    | 115      | 115            | 0                 |         | -                  |               | -                      |
| .03        | School Bank  | 1    | 165      | 165            | 0                 |         | -                  |               | -                      |
| .04        | Administrative/Student Personnel Copy Workroom       | 1    | 200      | 200            | 0                 |         | -                  |               | -                      |
|            | a. Supply/Storage Room                               | 1    | 270      | 270            | 0                 |         | -                  |               | -                      |
| .05        | E.R. Room  | 1    | 530      | 530            | 0                 |         | -                  |               | -                      |
|            | Office   | 1    | 120      | 120            | 0                 |         | -                  |               | -                      |
| .06        | Electrical Room                                      | 1    |          | 0              | 0                 |         | -                  |               | -                      |
| .07        | General Use Restrooms                                | 1    |          | 0              | 0                 |         | -                  |               | -                      |
| .08        | Office   | 2    | 120      | 240            | 0                 |         | -                  |               | -                      |
| .09        | Conference Room                                      | 1    | 425      | 425            | 0                 |         | -                  |               | -                      |
| .10        | Custodial Storage                                    | 1    | 50       | 50             | 0                 |         | -                  |               | -                      |
| .11        | Mail Room  | 1    | 200      | 200            | 0                 |         | -                  |               | -                      |
| .12        | Reprographics Room                                   | 1    | 470      | 470            | 0                 |         | -                  |               | -                      |
|            | a. Reprographics Room - Satellite                    | 2    | 120      | 240            | 0                 |         | -                  |               | -                      |
|            | b. Supply / Storage / Administrative / Reprographics | 1    | 595      | 595            | 0                 |         | -                  |               | -                      |
| .13        | Reception / Secretarial Office                       | 4    | 400      | 1,600          | 0                 |         | -                  |               | -                      |
|            | a. Storage Room                                      | 4    | 80       | 320            | 0                 |         | -                  |               | -                      |
|            |  |      |          | <b>6,830</b>   | <b>0</b>          |         | <b>0</b>           |               | <b>0</b>               |
| <b>1.2</b> | <b>Dean's / Development Office Complex</b>           |      |          |                |                   |         |                    |               |                        |
| .01        | Reception Area                                       | 1    | 655      | 655            | 0                 |         | -                  |               | -                      |
| .02        | Office   | 3    | 150      | 450            | 0                 |         | -                  |               | -                      |
| .03        | Office   | 3    | 120      | 360            | 0                 |         | -                  |               | -                      |
|            |  |      |          | <b>1,465</b>   | <b>0</b>          |         | <b>0</b>           |               | <b>0</b>               |
| <b>1.3</b> | <b>Principal's Area</b>                              |      |          |                |                   |         |                    |               |                        |
| .01        | Office   | 1    | 200      | 200            | 0                 |         | -                  |               | -                      |
| .02        | Office   | 1    | 120      | 120            | 0                 |         | -                  |               | -                      |
| .03        | Conference Room                                      | 1    | 425      | 425            | 0                 |         | -                  |               | -                      |
| .04        | Office   | 5    | 150      | 750            | 0                 |         | -                  |               | -                      |
|            |  |      |          | <b>1,495</b>   | <b>0</b>          |         | <b>0</b>           |               | <b>0</b>               |
| <b>1.4</b> | <b>Health Services Area</b>                          |      |          |                |                   |         |                    |               |                        |
| .01        | First Aid Workroom / Office                          | 1    | 375      | 375            | 0                 |         | -                  |               | -                      |
| .02        | Restroom (Single-Occ)                                | 2    |          | 0              | 0                 |         | -                  |               | -                      |
| .03        | First Aid Cot Area                                   |      |          | -              | 0                 |         | -                  |               | -                      |
|            | a. Well Room   | 1    | 175      | 175            | 0                 |         | -                  |               | -                      |
|            | b. Sick Room   | 1    | 175      | 175            | 0                 |         | -                  |               | -                      |
| .04        | T.R. Room  | 1    | 200      | 200            | 0                 |         | -                  |               | -                      |
|            |  |      |          | <b>925</b>     | <b>0</b>          |         | <b>0</b>           |               | <b>0</b>               |


# ADMINISTRATIVE CENTER

## 1.0 ADMINISTRATIVE CENTER


### 1.1 General Administrative Area




### 1.2 Dean's / Development Office Complex



### 1.3 Principal's Area




### 1.4 Health Services Area





# ROOM DATA SHEETS



## DESCRIPTION

Main public entrance. Relate to the Pupil Personnel Area for indirect access. Three clerks and five student aides. Area seating for 16 people. Provide window coverings.  
 Two 4' x 8' wall-mounted tackboards.  
 Two built-in trophy cases, approximately 8' wide x 18" deep x 9' high, entered vertically on the wall, approximately 18" A.F.F.  
 Built-in one level reception counters, 48" A.F.F. on the reception side, and 32" A.F.F. on the working side, with four duplex outlets, quadplex outlets as appropriate, undercounter storage with lockable bank drawer, one file drawer, and conduit for computer networking with cable back to the central computer rack. The raised portion of the desk should be high enough to stand binders under it. Make counters wide enough for (2) computer and keyboard stations, locate the electrical outlets for computer/keyboard under the desk and make one hole for each station in the counter top to run the electrical cords through (1 1/4" wide x 5" long).  
 The cupboards should be located on end of counter furthest away from the main entrance.  
 Drinking fountain on seating area side. ITV outlet. One clock / intercom..

## SERVICES

HVAC: Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: Yes


## FINISHES

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" to 12'-0"  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

## KEY

- RECEPTACLE
- QUAD RECEPTACLE
- DATA/PHONE
- FLOOR BOX (POWER & DATA)
- DATA
- TV OUTLET
- CLOCK/INTERCOM



## DESCRIPTION

1 clerk + 1 student aide. Minimum of 6 outlets. Fireproof room with unique lock storage, and access to record vault. Exterior window preferred.

## SERVICES

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

## FINISHES

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

## KEY

- RECEPTACLE
- QUAD RECEPTACLE
- DATA/PHONE
- FLOOR BOX (POWER & DATA)
- DATA
- TV OUTLET
- CLOCK/INTERCOM

## 1.1.01 | RECEPTION AREA


SCALE: 1/8" = 1'-0"

975 SF

## 1.1.02 | REGISTRAR'S OFFICE

SCALE: 3/16" = 1'-0"

315 SF



**DESCRIPTION**

Record vault attached to registrar's office. One hour fire rating.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No


**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Gypsum board  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Hollow metal, fire rated  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⏰ CLOCK/INTERCOM



**DESCRIPTION**

Service window on the student hallway side of the office for students. (Service window should have an outside counter for student use.) At one station service counter 34" A.F.F. with one abovecounter duplex outlet, undercounter storage, and undercounter lockable cash drawer. Lockable roll-up shutter on the inside of the window. One 4' x 4' wall-mounted tackboard. Closet safe (approximately 2 cu. ft., prefer rectangular and maximum 12" below floor level). Two data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. One quadruplex outlets related to desk location. One duplex outlet on walls without quadruplex outlets. One clock outlet near service window. Secure alarmed area. Two tall storage cabinets.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: NO

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⏰ CLOCK/INTERCOM

1.1.02A | RECORD VAULT


SCALE: 3/8" = 1'-0"

115 SF

1.1.03 | SCHOOL BANK

SCALE: 1/4" = 1'-0"

165 SF



**DESCRIPTION**

Accessible by all in Administrative Center. One 4' x 8' wall-mounted tackboard. One 4' x 8' marker board. Counter with sink, hot and cold water, and GFI outlets. One data port on opposite wall from mailbox unit per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. Mail box unit built-in with 160 slots (12" wide x 15" deep x 4" high) and 20 slots (12" wide x 15" deep x 13" high with lockable undercounter storage. Two duplex outlets and one quadplex outlet on each remaining wall. Dedicated circuit for console-mounted copier. Outlets not to be daisy chained. One clock / intercom. Two electric drinking fountains, one in compliance with ADA.

**SERVICES**

HVAC: Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 51  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

SCALE: 1/4" = 1'-0"

**1.1.04 | ADMIN / STUDENT PERSONEL WORKROOM**

200 SF



**DESCRIPTION**

Storage for all school supplies. Provide double door hallway delivery entrance.

**SERVICES**

HVAC: Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**FINISHES**

Floor: Sealed concrete  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

SCALE: 1/4" = 1'-0"

**1.1.04A | SUPPLY/STORAGE ROOM**

270 SF



### DESCRIPTION

E.R. in a central location within the facility. This room shall support the following systems: Data, ITV / CTV, telecommunications, clock / intercom, EMS, fire system, and UPS. Each cabinet / rack and ladder tray are to be properly grounded. Electrical power supported by Ups Tied into the site life / safety backup generator. Baby changing spaces to be located in public spaces only. Data wiring infrastructure and electrical power to support all required equipment / infrastructure. Provide HVAC supply and return air. One quadraplex outlet. Other power outlets as required. Landline - phone outlet.

### SERVICES








HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

### FINISHES

Floor: VCT static dissipative  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Open  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


### KEY

-  RECEPTACLE
-  QUAD RECEPTACLE
-  DATA/PHONE
-  FLOOR BOX (POWER & DATA)
-  DATA
-  TV OUTLET
-  CLOCK/INTERCOM

## 1.1.05 | E.R. ROOM

SCALE: 3/16" = 1'-0"

530 SF



### DESCRIPTION

Relate to E.R. Room. One 4' x 4' wall-mounted tackboard. Data port related to desk location per current CCSD standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. Two quadraplex outlets related to desk location. One duplex outlet on walls without quadraplex outlets. One clock outlet.

### SERVICES








HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

### FINISHES

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


### KEY

-  RECEPTACLE
-  QUAD RECEPTACLE
-  DATA/PHONE
-  FLOOR BOX (POWER & DATA)
-  DATA
-  TV OUTLET
-  CLOCK/INTERCOM

## 1.1.05A | OFFICE

SCALE: 1/4" = 1'-0"

120 SF



**DESCRIPTION**

Single user restrooms. Access from main hallway. Water closet and lavatory to meet code. Shatterproof mirror. One GFIC duplex outlet near lavatory. Liquid soap dispenser. Paper towel dispenser. Roll toilet paper dispenser. Sanitary napkin dispenser/disposal. Baby changing stations in public space restrooms only - Theater, Physical activity center and Student activity center. ADA accessible.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

**FINISHES**

Floor: Resinous flooring  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Gypsum board  
 Height: 9'-0" min.  
 CAC Rating: 51  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**


- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⏏ CLOCK/INTERCOM

1.1.07, 4.1.07, 4.3.02B,  
 7.1.02, 8.1.02, 10.2.02,  
 11.1.02, 12.1.02

**STAFF / GENERAL USE RESTROOM**

SCALE: 1/4" = 1'-0"

N/A



**DESCRIPTION**

An outlet on each wall and one wall with two. Prefer exterior window; must be private for confidentiality. Offices should be in close proximity to each other. Computer monitor not visible to students in the office.

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⏏ CLOCK/INTERCOM


**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

**1.1.08 OFFICE**

120 SF

SCALE: 1/4" = 1'-0"



**DESCRIPTION**

Large table with room to seat at least 15 people comfortably. AV Equipment for college visitations. One 4' x 8' wall-mounted tackboard. One 4' x 8' wall-mounted marker board at the front of the room. Provide power, data connections and backing at interactive flat panel locations. A minimum of one data port on a side wall per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. One quadplex outlet on each side wall. Additional duplex outlets on each wall per code. AV ready room - speaker and microphone integration capabilities. One clock / intercom located by the entrance door. Sound attenuation and isolation.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**1.1.09 | CONFERENCE ROOM**

SCALE: 3/16" = 1'-0"

425 SF



**DESCRIPTION**

Custodial storage with mop sink with hot/cold water and mop rack, (include FRP on side walls that are drywall). One duplex outlet.

**FINISHES**

Floor: Sealed concrete  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM


**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

**1.1.10 | CUSTODIAL STORAGE**

SCALE: 3/8" = 1'-0"

50 SF



**DESCRIPTION**

Mail box unit built-in with 160 slots (12" wide x 15" deep x 4" high) and 20 slots (12" wide x 15" deep x 13" high) with lockable undercounter storage. Clock intercom located near entrance.

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51


Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No



**DESCRIPTION**

Relate to teacher traffic.  
 One 4' x 8' wall-mounted tackboard.  
 Reception and receiving counter with undercounter storage at the teacher and delivery doors.  
 Built-in work counter, 36" A.F.F., 30" deep, on one wall including sink with hot and cold water, undercounter lockable storage, abovecounter electrical plugmold (24" O.C.), and abovecounter lockable storage. Electrical connections not to be daisy chained.  
 One computer station, 27" A.F.F., 30" deep and 36" wide with data port with conduit for computer networking with cable back to the central computer rack.  
 One quadplex outlet on each of three walls related to potential desk locations.  
 Electrical outlets (4' O.C.) on non-counter walls.  
 Electrical 220/240 volts, single phase, 30 amps circuit for printer.  
 Four duplex outlets in floor for other equipment (space locations away from printer).  
 Exhaust hood for offset press and duplication machines in central area of the room.  
 One clock / intercom viewable from both service counters.  
 Sound attenuation.

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 15'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110V, 220/240V  
 Data: Yes  
 AV: No

1.1.11 | MAIL ROOM

200 SF


SCALE: 3/16" = 1'-0"

1.1.12 | REPROGRAPHICS ROOM

470 SF

SCALE: 1/8" = 1'-0"





**DESCRIPTION**

Secondary reprographics room. Relate to teacher traffic.  
 One 4' x 8' wall-mounted tackboard.  
 One computer station, 27" A.F.F., 30" deep and 36" wide with data port with conduit for computer networking with cable back to the central computer rack.  
 One quadraplex outlet on each of three walls related to potential desk locations.  
 One clock outlet.  
 Sound attenuation.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110V,220/240V  
 Data: Yes  
 AV: No


**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 15'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM



**DESCRIPTION**

Storage for all school supplies.  
 Provide double door entry off hallway.  
 Two duplex outlets on each wall. Quad on two walls.  
 Data for potential printer connection.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110V,220/240V  
 Data: Yes  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

1.1.12A | REPROGRAPHICS ROOM - SATELLITE

SCALE: 1/4" = 1'-0"



120 SF

1.1.12B | SUPPLY/STORAGE ADMIN/REPROGRAPHICS

SCALE: 1/8" = 1'-0"

595 SF





**DESCRIPTION**

Access to counseling offices. Proximity to Registrar's Office. Receptionist desk situated to control access to counseling office. Windows into counseling offices with blinds. Printer area. Student aide work area. Laptop station for printing (no more than 5). A large area where a laptop for student check-in can be placed. The monitor hidden from parents/students. Clock/intercom.

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite / Storefront  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110V, 220/240V  
 Data: Yes  
 AV: No

**DESCRIPTION**

Direct access from Reception/ Secretarial Office. One duplex outlet.

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**1.1.13 | RECEPTION / SECRETARIAL OFFICE**


SCALE: 3/16" = 1'-0"

400 SF

**1.1.13A | STORAGE ROOM**

SCALE: 3/8" = 1'-0"

80 SF



**DESCRIPTION**

Controls access to Deans' Offices. One clerk and two student aides. One 4' x 8' wall-mounted tackboard. Space for two computer workstations (min. configurations 84" x 108") each. Data ports at potential desk locations per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. Two quadraplex outlets on long walls and one quadraplex outlet on each short wall. One additional duplex outlet on each wall. One ITV outlet. One clock / intercom. Secure area.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite /Storefront  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ◻ CLOCK/INTERCOM

**1.2.01 | RECEPTION AREA**

SCALE: 3/16" = 1'-0"

655 SF



**DESCRIPTION**

Related to Reception Area for access. One 4' x 4' wall-mounted tackboard. Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. One quadraplex outlet on each of two walls related to desk location. One duplex outlet on each remaining wall. One clock / intercom. Sound attenuation and sound isolation.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ◻ CLOCK/INTERCOM

**1.2.02 | OFFICE**

SCALE: 1/4" = 1'-0"

150 SF



**DESCRIPTION**

Relate to Reception Area for access.  
 One 4' x 4' wall-mounted tackboard. Data ports related to desk locations per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. Two quadraplex outlets related to desk locations. One duplex outlet on walls without quadraplex outlets.  
 One clock / intercom.  
 Sound attenuation and isolation.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**1.2.03 | OFFICE**

SCALE: 1/4" = 1'-0"

120 SF



**DESCRIPTION**

Limited student traffic. Direct access to 1.3.02 office. Direct access to conference room.  
 One 4' x 4' wall-mounted tackboard. One 4' x 4' wall-mounted markerboard.  
 Data ports related to potential desk locations per current CCSD Standard premise wiring matrix with conduit for three computer outlets for computer networking with cable back to the central computer rack. A minimum of three quadraplex outlets related to potential desk locations. Additional duplex outlets on walls without quadraplex outlets. One phone outlet for principal hot line. One clock / intercom.  
 Sound attenuation and sound isolation.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**1.3.01 | OFFICE**

SCALE: 1/4" = 1'-0"

200 SF



**DESCRIPTION**

Controls access to 1.3.01 office and conference room. One 4' x 4' wall-mounted tackboard. Space for computer work station (min. 84" x 108" configuration). A minimum of two data ports related to desk locations per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. A minimum of two quadraplex outlets related to desk locations. One duplex outlet on remaining wall. One clock / intercom located by entrance door.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite

STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**1.3.02 | OFFICE**

SCALE: 1/4" = 1'-0"

120 SF



**DESCRIPTION**

Direct access from principal's office. Seating for 20 at a 20' x 4' conference table. One 4' x 8' wall-mounted tackboard. One 4' x 8' wall-mounted marker board at the front of the room. Provide power, data connections and backing at interactive flat panel locations. A minimum of one data port on a side wall per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. One quadraplex outlet on each side wall. Additional duplex outlets on each wall per code. AV ready room - speaker and microphone integration capabilities. One clock / intercom located by the entrance door. Sound attenuation and isolation. Kitchenette on one wall with built-in casework, sink and refrigerator. Electrical not to be daisy-chained at kitchenette.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: Yes

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**1.3.03 | CONFERENCE ROOM**

SCALE: 3/16" = 1'-0"

425 SF



**DESCRIPTION**

Limited student traffic.  
 One 4' x 4' wall-mounted tackboard. One 4' x 4' wall-mounted markerboard. Data ports related to potential desk locations per current CCSD Standard premise wiring matrix with conduit for three computer outlets for computer networking with cable back to the central computer rack. A minimum of three quadruplex outlets related to potential desk locations. Additional duplex outlets on walls without quadruplex outlets. One ITV outlet. One CTV outlet.  
 One clock / intercom near entry door.  
 Sound attenuation and sound isolation.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite

STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**1.3.04 | OFFICE**

SCALE: 1/4" = 1'-0"

150 SF



**DESCRIPTION**

Relate to Reception Area for access.  
 Separate office within area with direct access to 1st aid workroom. Door to corridor from 1st aid workroom.  
 All doorways should be ADA accessible (3' - 4" entrance doors are preferred).  
 Visual supervision with blinds from office to 1st aid workroom and cot area.  
 One 4' x 4' wall-mounted tackboard in office. One 4' x 8' wall-mounted tackboard in workroom area.  
 Built-in work counter 34" A.F.F. with sink (sink should not be behind the door), faucet with hot and cold water, (eye wash on faucet), work-light under the abovecounter shelving and over the sink area, abovecounter electrical plugmold (electrical connections not to be daisy chained), abovecounter lockable storage with adjustable shelving, and undercounter storage with adjustable shelving, lockable doors, and lockable drawers in the 1st aid workroom. Area and power for 6 cu. ft. refrigerator/freezer in 1st aid room.  
 Data ports in office and one data port in 1st aid workroom per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack in health services office area. One quadruplex outlet on each of two walls related to desk locations. One additional duplex outlet on each wall.  
 Non-textured painted enamel walls. Clock / intercom in office and workroom.

**FINISHES**

Floor: VCT  
 Walls: Painted enamel  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM


**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: No

**1.4.01 | FIRST AID WORKROOM / OFFICE**

SCALE: 1/8" = 1'-0"

375 SF



**DESCRIPTION**

Access from hallway.  
 Support of students visiting health services area.  
 Rest Room assignable Include space for a chair.  
 One S. S. wall mounted towel pin on back of door.  
 Water closet and lavatory to meet code.  
 Shatterproof mirror(s).  
 One GFIC duplex outlet.  
 Soap dispenser(s). (OFOL)  
 Paper towel dispenser(s).  
 Roll toilet paper dispenser(s).  
 One shower with toweling/changing area.  
 ADA accessible with flex hose, grab bars, fold up shower seat, and other accessories to meet code.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No


**FINISHES**

Floor: Resinous flooring  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Gypsum board  
 Height: 9'-0" min.  
 CAC Rating: 51  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⊖ CLOCK/INTERCOM



**DESCRIPTION**

Visual supervision from workroom area. Used for therapy, examination and rest.  
 Two 6' 1st aid couches. Drapes for one 1st aid couch in the isolation area (one couch area next to the 1st aid work area should have complete drape isolation).  
 One wall mounted towel pin on the wall behind each couch.  
 Non- textured painted enamel walls.  
 Clock / intercom near entry door.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Painted enamel  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⊖ CLOCK/INTERCOM

1.4.02 | GENERAL USE RESTROOM


SCALE: 1/4" = 1'-0"

N/A

1.4.03A | WELL ROOM

SCALE: 1/4" = 1'-0"

175 SF



**DESCRIPTION**

Visual supervision from office area. Used for therapy, examination and rest of students not feeling well.  
 Access from workroom. Two 6' 1st aid couches.  
 Drapes for one 1st aid couch in the isolation area (one couch area next to the 1st aid work area should have complete drape isolation).  
 One wall mounted towel pin on the wall behind each couch.  
 Non- textured painted enamel walls.  
 Clock / intercom near entry door.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: No


**FINISHES**

Floor: VCT  
 Walls: Painted enamel  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⊏ CLOCK/INTERCOM



**DESCRIPTION**

Three rack telecommunication room.  
 Backboard for telephone, ITV / CTV and security wiring.  
 Electrical power within the TR Room for the ITV / CTV system and for each cabinet / rack.  
 Provide ladder tray for cable management above the cabinet / rack.  
 Each cabinet / rack and ladder tray are to be properly grounded.  
 Provide one duplex electrical outlet adjacent to each individual data port.

**SERVICES**

HVAC: Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: VCT static dissipative  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Open  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⊏ CLOCK/INTERCOM

1.4.03B | SICK ROOM

175 SF

SCALE: 1/4 = 1'-0"

1.4.04, 2.2.06, 3.5.05, 3.6.03,  
 4.1.04, 6.1.05, 10.2.05,  
 11.1.04, 12.1.04

200 SF

SCALE: 1/4 = 1'-0"

TR ROOM

# 02 FINE AND PERFORMING ARTS CENTER



# FINE AND PERFORMING ARTS CENTER

|            |  |               |          |            |            |
|------------|--|---------------|----------|------------|------------|
| <b>2.0</b> | <b>FINE AND PERFORMING ARTS CENTER</b> | <b>21,190</b> | <b>4</b> | <b>120</b> | <b>100</b> |
|------------|--|---------------|----------|------------|------------|


| 2.1 Music Classrooms |                            | Qty. | Net Area | Total Net Area | Teaching #T.S. | # Stud. | Capacity @ 100% | Utilization % | Functional Capacity |
|----------------------|----------------------------|------|----------|----------------|----------------|---------|-----------------|---------------|---------------------|
| .01                  | Band Classroom             | 1    | 3,435    | 3,435          | 1              | 30      | 30              | 83%           | 25                  |
|                      | a. Music Department Office | 1    | 285      | 285            | 0              |         | -               |               | -                   |
|                      | b. Music Library           | 1    | 130      | 130            | 0              |         | -               |               | -                   |
|                      | c. Percussion Storage Room | 1    | 150      | 150            | 0              |         | -               |               | -                   |
|                      | d. Instrument Storage Room | 1    | 395      | 395            | 0              |         | -               |               | -                   |
|                      | e. Ensemble Room           | 1    | 205      | 205            | 0              |         | -               |               | -                   |
| .02                  | Orchestra Classroom        | 1    | 1,355    | 1,355          | 1              | 30      | 30              | 83%           | 25                  |
|                      | a. Instrument Storage Room | 1    | 325      | 325            | 0              |         | -               |               | -                   |
|                      | b. Practice Room           | 1    | 105      | 105            | 0              |         | -               |               | -                   |
| .03                  | Choral Classroom           | 1    | 1,540    | 1,540          | 1              | 30      | 30              | 83%           | 25                  |
|                      | a. Robe Storage Room       | 1    | 145      | 145            | 0              |         | -               |               | -                   |
|                      | b. Practice Room           | 1    | 105      | 105            | 0              |         | -               |               | -                   |
| .04                  | T.R. Room                  | 1    | 200      | 200            | 0              |         | -               |               | -                   |
|                      |                            |      |          | <b>8,375</b>   | <b>3</b>       |         | <b>90</b>       |               | <b>75</b>           |

| 2.2 Theater Complex |                                   | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | Capacity @ 100% | Utilization % | Capacity  |
|---------------------|-----------------------------------|------|----------|----------------|----------|---------|-----------------|---------------|-----------|
| .01                 | Theater Lobby                     | 1    | 750      | 750            | 0        |         | -               |               | -         |
|                     | a. Theater Vestibule              | 1    | 250      | 250            | 0        |         | -               |               | -         |
|                     | b. General Use Restroom           | 1    |          | 0              | 0        |         | -               |               | -         |
|                     | c. Custodial Storage              | 1    | 65       | 65             | 0        |         | -               |               | -         |
| .02                 | Theater Seating                   | 1    | 5,270    | 5,270          | 0        |         | -               |               | -         |
| .03                 | Stage                             | 1    | 2,450    | 2,450          | 0        |         | -               |               | -         |
|                     | a. Vestibule                      | 1    | 125      | 125            | 0        |         | -               |               | -         |
| .04                 | Control Room                      | 1    | 705      | 705            | 0        |         | -               |               | -         |
| .05                 | Drama Classroom                   | 1    | 1,165    | 1,165          | 1        | 30      | 30              | 83%           | 25        |
|                     | a. Office                         | 1    | 120      | 120            | 0        |         | -               |               | -         |
|                     | b. Property Construction Storage  | 1    | 1,035    | 1,035          | 0        |         | -               |               | -         |
|                     | c. Prop Storage                   | 1    | 330      | 330            | 0        |         | -               |               | -         |
|                     | d. Exterior courtyard             | 1    |          | 0              | 0        |         | -               |               | -         |
|                     | e. Girl's Dressing / Waiting Room | 1    | 175      | 175            | 0        |         | -               |               | -         |
|                     | f. Girl's Performer's Restroom    | 1    |          | 0              | 0        |         | -               |               | -         |
|                     | g. Boy's Dressing / Waiting Room  | 1    | 175      | 175            | 0        |         | -               |               | -         |
|                     | h. Boy's Performer's Restroom     | 1    |          | 0              | 0        |         | -               |               | -         |
| .06                 | TR Room                           | 1    | 200      | 200            | 0        |         | -               |               | -         |
|                     |                                   |      |          | <b>12,815</b>  | <b>1</b> |         | <b>30</b>       |               | <b>25</b> |


# FINE AND PERFORMING ARTS CENTER

## 2.0 FINE AND PERFORMING ARTS CENTER


### 2.1 Music Classrooms



### 2.2 Theater Complex



# ROOM DATA SHEETS



## DESCRIPTION

Relate to stage and backstage areas for access.  
 Band and orchestra instruction and rehearsals.  
 Oversized entrance (for instruments) no mullions in doorways.  
 Two 4' x 8' wall-mounted tackboards, one near the entrance. Two 4' x 8' wall-mounted music lined, marker boards. Two 4' x 8' wall-mounted marker boards.  
 One 4' counter with undercounter storage cabinet with HCP sink with hot and cold water and abovecounter GFIC duplex outlet.  
 Space on one classroom wall for modular wardrobe/cabinet instrument storage for instruments listed in CCSD Equipment Standards.  
 Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 Three power outlets to include quadplex outlets related to data ports and additional duplex outlets on each non-storage unit wall.  
 Provide power, data connections and wall blocking at interactive flat panel locations.  
 Clock / intercom with call button 48" A.F.F.  
 Performance level audio and video recording capabilities.

## SERVICES

HVAC Room Noise Criteria (dBA): 30  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: Yes


## CRITERIA

Floor: Carpet  
 Walls: Paint  
 STC Rating: 79  
 Ceiling: ACT  
 Height: 25'-0" min.  
 CAC Rating: 40  
 Doors: Solid core door  
 STC Rating: 79

Note: Use Acoustical Engineer for all spaces

## KEY

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⊏ CLOCK/INTERCOM



## DESCRIPTION

Direct access from Band Classroom.  
 Window for visual supervision of Band Classroom.  
 One 4' x 8' wall-mounted tackboard  
 Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 One quadplex outlet on each of two walls related to dataports and desk locations.  
 One duplex outlet on each remaining wall.  
 One clock / intercom.

## SERVICES

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

## CRITERIA

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Aluminum with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

## KEY

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⊏ CLOCK/INTERCOM

## 2.1.01 | BAND CLASSROOM


3,435 SF

SCALE: 1/16" = 1'-0"

## 2.1.01A | MUSIC DEPARTMENT OFFICE

285 SF

SCALE: 3/16" = 1'-0"



**DESCRIPTION**

Centralized music library, hallway access.  
Teacher preparation and sheet music storage.  
Two duplex outlets.

**CRITERIA**

Floor: Carpet  
Walls: Paint  
STC Rating: 51  
Ceiling: ACT  
Height: 9'-0" min.  
CAC Rating: 40  
Doors: Solid core wood with vision lite  
STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): -  
Plumbing: No  
Power: 110v  
Data: No  
AV: No


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**2.1.01B | MUSIC LIBRARY**

SCALE: 1/4" = 1'-0"

130 SF



**DESCRIPTION**

Direct access from Band Classroom.  
Door should be wide enough to accommodate timpani drums (no mullion in doorways).  
Storage of percussion instruments.  
Three duplex outlets.

**CRITERIA**

Floor: VCT  
Walls: Paint  
STC Rating: -  
Ceiling: ACT  
Height: 9'-0" min.  
CAC Rating: 40  
Doors: Solid core wood  
STC Rating: -

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): -  
Plumbing: No  
Power: 110v  
Data: No  
AV: No


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**2.1.01C | PERCUSSION STORAGE ROOM**

SCALE: 1/4" = 1'-0"

150 SF



**DESCRIPTION**

Direct access from Band Classroom.  
Storage of large and small instruments.  
Four duplex outlets.

**CRITERIA**

Floor: VCT  
Walls: Paint  
STC Rating: 51  
Ceiling: ACT  
Height: 9'-0" min.  
CAC Rating: 40  
Doors: Solid core with vision lite  
STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
Plumbing: No  
Power: 110v  
Data: No  
AV: No


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**2.1.01D | INSTRUMENT STORAGE ROOM**

SCALE: 3/16" = 1'-0"

395 SF



**DESCRIPTION**

Instrument practice room.  
Two duplex outlets, two quads.  
Clock / intercom near entry door.  
Provide power, data connections and wall blocking at interactive flat panel locations.  
Sound isolation and attenuation.

**CRITERIA**

Floor: Carpet  
Walls: Paint  
STC Rating: 79  
Ceiling: ACT  
Height: 9'-0" min.  
CAC Rating: 40  
Doors: Solid core with vision lite  
STC Rating: 79

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 30  
Plumbing: No  
Power: 110v  
Data: No  
AV: Yes


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**2.1.01E | ENSEMBLE ROOM**

SCALE: 3/16" = 1'-0"

205 SF



**DESCRIPTION**

Relate to stage and backstage areas for access.  
 Double door access with no mullion in doorways.  
 Strings instruction and rehearsal.  
 One 4' x 8' wall-mounted tackboard near the entrance.  
 One 4' x 8' wall-mounted music lined, marker board.  
 One 4' x 8' wall-mounted marker board.  
 Provide wall blocking, power and data for interactive flat panels.  
 Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 Three power outlets to include quadruplex outlets related to data ports and additional duplex outlets on each wall.  
 One clock / intercom with call button 48" A.F.F.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

**CRITERIA**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 12'-0" min.  
 CAC Rating: 40  
 Doors: Solid core with vision lite  
 STC Rating: 79

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**2.1.02 | ORCHESTRA CLASSROOM**

SCALE: 3/32" = 1'-0"

1,355 SF



**DESCRIPTION**

Direct access from student orchestra room.  
 Storage of large and small instruments.  
 Four duplex outlets.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**CRITERIA**

Floor: VCT  
 Walls: Paint  
 STC Rating: -  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: -

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**2.1.02A | INSTRUMENT STORAGE ROOM**

SCALE: 3/16" = 1'-0"

325 SF



**DESCRIPTION**

Instrument practice room.  
Two duplex outlets.  
Provide power, data connections and wall blocking at interactive flat panel locations.  
Clock / intercom with call button 48" A.F.F.  
Sound isolation and attenuation.

**CRITERIA**

Floor: Wood  
Walls: Paint  
STC Rating: 79  
Ceiling: ACT  
Height: 9'-0" min.  
CAC Rating: 40  
Doors: Solid core with vision lite  
STC Rating: 79

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 30  
Plumbing: No  
Power: 110v  
Data: No  
AV: Yes


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**2.1.02B | PRACTICE ROOM**

SCALE: 1/4" = 1'-0"

105 SF



**DESCRIPTION**

Relate to stage and backstage areas for access.  
Vocal music instruction and rehearsals.  
Oversized entrance (for piano) no mullions in doorways.  
Include built-in riser storage.  
Two 4' x 8' wall-mounted tackboards, one near the entrance.  
Two 4' x 8' wall-mounted music lined, marker boards.  
One 4' x 8' wall-mounted marker board.  
Provide wall blocking, power and data for interactive flat panels.  
Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
Three power outlets with quadruplex outlets related to dataports and additional duplex outlets on each wall.  
One clock / intercom with call button 48" A.F.F.

**CRITERIA**

Floor: Carpet  
Walls: Paint  
STC Rating: 79  
Ceiling: ACT  
Height: 12'-0" min.  
CAC Rating: 40  
Doors: Solid core wood  
STC Rating: 79

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 30  
Plumbing: No  
Power: 110v  
Data: Yes  
AV: Yes


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**2.1.03 | CHORAL CLASSROOM**

SCALE: 1/8" = 1'-0"

1,540 SF



**DESCRIPTION**

Direct access from Choral Classroom.  
Storage of choral robes and electrical equipment.  
Two duplex outlets.

**CRITERIA**

Floor: VCT  
Walls: Paint  
STC Rating: -  
Ceiling: ACT  
Height: 9'-0" min.  
CAC Rating: 40  
Doors: Solid core wood  
STC Rating: -

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): -  
Plumbing: No  
Power: 110v  
Data: No  
AV: No


**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**2.1.03A | ROBE STORAGE**

SCALE: 3/16" = 1'-0"

145 SF



**DESCRIPTION**

Vocal practice room.  
Provide power, data connections and wall blocking at interactive flat panel locations.  
Clock / intercom with call button 48" A.F.F.  
Sound isolation and attenuation.

**CRITERIA**

Floor: Carpet  
Walls: Paint  
STC Rating: 79  
Ceiling: ACT  
Height: 9'-0" min.  
CAC Rating: 40  
Doors: Solid core wood with vision lite  
STC Rating: 79

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 30  
Plumbing: No  
Power: 110v  
Data: No  
AV: Yes

**KEY**


- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**2.1.03B | PRACTICE ROOM**

SCALE: 1/4" = 1'-0"

105 SF





**DESCRIPTION**

Relate to student parking lot for public access. Serve as controlled main public entrance. Refrigerated drinking fountains. Built-in lockable trophy case with lockable storage under the case. Two duplexes outlets or to meet code.  
One clock / intercom with call button 48" A.F.F.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: No


**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Gypsum board  
 Height: 12'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood / Storefront  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⊖ CLOCK/INTERCOM



**DESCRIPTION**

Entrance to theater seating.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Gypsum board  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⊖ CLOCK/INTERCOM

2.2.01 | THEATER LOBBY


SCALE: 1/8" = 1'-0"

750 SF

2.2.01A | THEATER VESTIBULE

SCALE: 1/8" = 1'-0"

250 SF



**DESCRIPTION**

Custodial storage with mop sink with hot/cold water and mop rack, (include FRP on side walls that are drywall). One duplex outlet.

**FINISHES**

|             |                 |
|-------------|-----------------|
| Floor:      | Sealed concrete |
| Walls:      | Paint           |
| STC Rating: | 51              |
| Ceiling:    | ACT             |
| Height:     | 9'-0" min.      |
| CAC Rating: | 40              |
| Doors:      | Solid core wood |
| STC Rating: | 51              |

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊞ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM


**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

**2.2.01C | CUSTODIAL STORAGE**

SCALE: 3/8" = 1'-0"

65 SF



**DESCRIPTION**

499 seats.  
 Easy access to stage or backstage.  
 Sloped or terraced fixed seating.  
 Provide a right hand folding tablet arm (12" x 13") with each seat in each row except for the last seat at the left end of the row. Provide a left hand tablet arm (12" x 13") for each last seat at the left end of the row of each row.  
 Provide appropriate number of open spaces for wheelchair HCP persons in addition to the fixed seating.  
 Level area around the stage.  
 Assistive listening system for hearing impaired. Infra red in conjunction with the P.A. systems to accommodate a minimum of eight receivers.  
 Duplex outlets; locate two on each wall and two flush floor mounted in the center isle for audio visual equipment.  
 Two ITV outlets; locate one on each side in the front of the stage).  
 One CTV outlet located at the front of the stage near one of the ITV locations. Full size walkable lighting grid with 20' clearance. Sound channels more than 6 < 50. Multiple path points and data points in grid and walls. Mid-tech level should be 3 sides minimum at central locations. Air lock for backstage.

**SERVICES**

HVAC Room Noise Criteria (dBA): 30  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

**FINISHES**

|             |                                |
|-------------|--------------------------------|
| Floor:      | Carpet                         |
| Walls:      | Paint                          |
| STC Rating: | 79                             |
| Ceiling:    | Exposed with acoustical panels |
| Height:     | 25'-0" min.                    |
| CAC Rating: | 40                             |
| Doors:      | Hollow metal with vision lite  |
| STC Rating: | 79                             |

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊞ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**2.2.02 | THEATER SEATING**

SCALE: 1/16" = 1'-0"

5,270 SF



**DESCRIPTION**

Stage to have 15' x 20' ceiling hung motorized electric projection screen located at the back of the stage, appropriate theatrical stage rigging for performances and fly space. Theater microphone and P.A. system capability. Four electrical outlets in the stage floor and quadplex outlets to support data outlets. Provides auxiliary stage lighting control wall receptacle. One ITV/CTV outlet to be located at the back of the stage, one data port to be located in front and one located in the back. One clock / intercom with call button 48" A.F.F. Handicapped accessible. Rectangular raised wood floor surface. Theatrical drapes hung at front of stage and cyclorama curtains at back wall.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes


**FINISHES**

Floor: Wood  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Open  
 Height: -  
 CAC Rating: 40  
 Doors: -  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM



**DESCRIPTION**

Backstage area. Double door vestibule access to acting studios with single door access to stage. Double door access to theatre seating. Double door outside access.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

2.2.03 | STAGE



SCALE: 1/16" = 1'-0"

2450 SF

2.2.03A | VESTIBULE

SCALE: 3/16" = 1'-0"

125 SF



**DESCRIPTION**

(Second floor) operable window is required.  
 Space for equipment and operators.  
 Direct view of stage from audience side.  
 Control of stage and house lights, sound, film, stage motorized screen, and slide projectors.  
 Three duplex outlets and data ports in addition to electrical power for contractor supplied items.  
 clock / intercom near entry door.  
 One itv outlet.  
 Secure room.

**FINISHES**

Floor: VCT - Static Dissipative  
 Walls: Paint  
 STC Rating: 79  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 79

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 30  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**DESCRIPTION**

Folding wall between Drama Classroom and Stage (2.2.03).  
 Outside access door.  
 One 4' x 8' wall-mounted tackboard near the main entrance.  
 Two 4' x 8' wall-mounted marker boards located at the front of classroom.  
 Provide wall blocking, power and data for interactive flat panels.  
 One 20" deep clean-up sink  
 Quadraplex outlets related to data port location with three duplex outlets on each wall.  
 One ITV outlet.  
 One clock / intercom.  
 One drinking fountain.

**FINISHES**

Floor: Sprung floor with paintable masonite  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Exposed with acoustical panels  
 Height: 20'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: Yes

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**2.2.04 | CONTROL ROOM**


SCALE: 1/8" = 1'-0"

705 SF

**2.2.05 | DRAMA CLASSROOM**

SCALE: 3/32" = 1'-0"

1,165 SF



**DESCRIPTION**

Direct access to Drama Classroom.  
 One 4' x 4' wall-mounted tackboard.  
 Two quadraplex outlets.  
 One duplex outlet on each wall.  
 One clock / intercom with call button 48" A.F.F.

**CRITERIA**

Floor: Carpet  
 Walls: Paint  
     STC Rating: 51  
 Ceiling: ACT  
     Height: 9'-0" min.  
     CAC Rating: 40  
 Doors: Solid core wood with vision lite  
     STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No


**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ⏰ CLOCK/INTERCOM

**2.2.05A | OFFICE**

SCALE: 1/4" = 1'-0"

120 SF



**DESCRIPTION**

Double doors between Drama Classroom and Property Construction Storage (no mullion in door).  
 Appropriate ventilation and exhaust.  
 Storage of furniture, supplies, costumes, equipment, lights.  
 Area for construction, painting, and storage of scenery and stage props.  
 Area for 48" wide x 54" deep x 112" high storage rack.  
 One 20" deep clean-up sink.  
 One 125v special purpose power outlet.  
 One 250/20A special purpose outlet.  
 Electrical power outlets dedicated to accommodate theater equipment.  
 Nine outlets: (1) 120v/13 amp circuit, (1) 115v/30 amp circuit, and (7) 115v/20 amp circuit.  
 One clock / intercom.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v, 25v, 250v/20A, 120v/13 amp circuit, 115v/30 amp, 115v/20 amp circuit  
 Data: Yes  
 AV: No

**FINISHES**

Floor: Sealed concrete  
 Walls: Paint  
     STC Rating: 51  
 Ceiling: Open  
     Height: -  
     CAC Rating: 40  
 Doors: Solid core wood  
     STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ⏰ CLOCK/INTERCOM

**2.2.05B | PROPERTY CONSTRUCTION STORAGE**

SCALE: 1/8" = 1'-0"

1,035 SF



**DESCRIPTION**

Direct access from property construction storage.  
 Lockable double door with no mullion in door.  
 Lockable single door.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**FINISHES**

Floor: Sealed concrete  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Open  
 Height: -  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- Ⓛ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- Ⓛ CLOCK/INTERCOM

**2.2.05C | PROP STORAGE**

SCALE: 1/4" = 1'-0"

330 SF



**DESCRIPTION**

Area for (6) lockers 16" deep x 12" wide x 60" high (five tier).  
 One wall for make-up counter/shatterproof mirrors and lights with two sinks with hot and cold water and above counter electrical (gfc) plugmold with outlets 18" o.c. One wall-mounted, full length shatterproof mirror. One duplex outlet on each wall. Pipe rack for hanging clothes. One clock / intercom.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51  
 Hardware: Classroom lock

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- Ⓛ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- Ⓛ CLOCK/INTERCOM

**2.2.05E, 2.2.05G | GIRLS' AND BOYS' DRESSING/WAITING ROOM**

SCALE: 3/16" = 1'-0"

175 SF

# 03 PHYSICAL EDUCATION CENTER

# PHYSICAL EDUCATION CENTER

| <b>3.0</b> |   | <b>PHYSICAL EDUCATION CENTER</b> |          |                | <b>51,980</b>     | <b>9</b> | <b>390</b>         |               | <b>325</b>             |
|------------|---|----------------------------------|----------|----------------|-------------------|----------|--------------------|---------------|------------------------|
| <b>3.1</b> | <b>Athletic Administration Area</b>           | Qty.                             | Net Area | Total Net Area | Teaching<br>#T.S. | # Stud.  | Capacity<br>@ 100% | Utilization % | Functional<br>Capacity |
| .01        | Athletic Director Office                      | 1                                | 120      | 120            | 0                 |          | -                  |               | -                      |
| .02        | Security/Police Campus Monitor                | 1                                | 170      | 170            | 0                 |          | -                  |               | -                      |
|            |   |                                  |          | <b>290</b>     | <b>0</b>          |          | <b>0</b>           |               | <b>0</b>               |
| <b>3.2</b> | <b>Gymnasium Area</b>                         | Qty.                             | Net Area | Total Net Area | #T.S.             | # Stud.  | @ 100%             | Utilization % | Capacity               |
| .01        | Gymnasium Lobby                               | 1                                | 1,995    | 1,995          | 0                 |          | -                  |               | -                      |
|            | a. Concession Booth                           | 1                                | 310      | 310            | 0                 |          | -                  |               | -                      |
|            | b. Student Store                              | 1                                | 230      | 230            | 0                 |          | -                  |               | -                      |
|            | c. Storage Room                               | 1                                | 80       | 80             | 0                 |          | -                  |               | -                      |
|            | d. General Use Restroom                       | 1                                |          | 0              | 0                 |          | -                  |               | -                      |
| .02        | Gymnasium Floor (Size Midway between 18 & 15) | 1                                | 19,425   | 19,425         | 4                 | 50       | 200                | 83%           | 167                    |
|            | a. Bleachers                                  | 1                                |          | 0              | 0                 |          | -                  |               | -                      |
| .03        | Women's Team Storage Room                     | 1                                | 370      | 370            | 0                 |          | -                  |               | -                      |
| .04        | Men's Team Storage Room                       | 1                                | 370      | 370            | 0                 |          | -                  |               | -                      |
| .05        | Performing Group Storage and Meeting Room     | 1                                | 280      | 280            | 0                 |          | -                  |               | -                      |
| .06        | Auxiliary Gymnasium                           | 1                                | 6,930    | 6,930          | 2                 | 50       | 100                | 83%           | 83                     |
|            | a. Auxiliary Gymnasium Storage                | 1                                | 270      | 270            | 0                 |          | -                  |               | -                      |
| .07        | Custodial Storage Room                        | 1                                | 150      | 150            | 0                 |          | -                  |               | -                      |
| .08        | T.R. Room                                     | 1                                | 200      | 200            | 0                 |          | -                  |               | -                      |
| .09        | Equipment Storage (Football)                  | 1                                | 420      | 420            | 0                 |          | -                  |               | -                      |
|            |   |                                  |          | <b>31,030</b>  | <b>6</b>          |          | <b>300</b>         |               | <b>250</b>             |
| <b>3.3</b> | <b>Girl's Locker Area</b>                     | Qty.                             | Net Area | Total Net Area | #T.S.             | # Stud.  | @ 100%             | Utilization % | Capacity               |
| .01        | Girl's Locker Area                            | 1                                | 3,100    | 3,100          | 0                 |          | -                  |               | -                      |
| .02        | Girl's Shower/Towelng Area                    | 1                                | 120      | 120            | 0                 |          | -                  |               | -                      |
| .03        | Washer/Dryer Room                             | 1                                | 140      | 140            | 0                 |          | -                  |               | -                      |
| .04        | Girl's P.E. Restroom                          | 1                                |          | 0              | 0                 |          | -                  |               | -                      |
| .05        | Varsity Team Room/ First Aid Room             | 1                                | 735      | 735            | 0                 |          | -                  |               | -                      |
| .06        | Team Storage Rooms                            | 5                                | 90       | 450            | 0                 |          | -                  |               | -                      |
| .07        | Women's P.E. Staff Office                     | 1                                | 450      | 450            | 0                 |          | -                  |               | -                      |
|            | a. Women's PE Staff Locker/Shower Room        | 1                                | 100      | 100            | 0                 |          | -                  |               | -                      |
|            |   |                                  |          | <b>5,095</b>   | <b>0</b>          |          | <b>0</b>           |               | <b>0</b>               |



# PHYSICAL EDUCATION CENTER

| <b>3.4 Boy's Locker Area</b> |                                      | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|------------------------------|--------------------------------------|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01                          | Boy's Locker Area                    | 1    | 3,100    | 3,100          | 0        |         | -        |               | -        |
| .02                          | Boy's Shower/Toweling Area           | 1    | 120      | 120            | 0        |         | -        |               | -        |
| .03                          | Washer/Dryer Room                    | 1    | 140      | 140            | 0        |         | -        |               | -        |
| .04                          | Boy's P.E. Restroom                  | 1    |          | 0              | 0        |         | -        |               | -        |
| .05                          | Varsity Team Room/ First Aid Room    | 1    | 735      | 735            | 0        |         | -        |               | -        |
| .06                          | Team Storage Rooms                   | 5    | 90       | 450            | 0        |         | -        |               | -        |
| .07                          | Men's P.E. Staff Office              | 1    | 450      | 450            | 0        |         | -        |               | -        |
|                              | a. Men's PE Staff Locker/Shower Room | 1    | 100      | 100            | 0        |         | -        |               | -        |
|                              |                                      |      |          | <b>5,095</b>   | <b>0</b> |         | <b>0</b> |               | <b>0</b> |


| <b>3.5 Exercise, Weight, and Wrestling Room</b> |   | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%    | Utilization % | Capacity  |
|---|---|------|----------|----------------|----------|---------|-----------|---------------|-----------|
| .01   | Exercise Room / Functional Fitness / Wellness | 2    | 1,705    | 3,410          | 2        | 30      | 60        | 83%           | 50        |
|   | a. Storage Room                               | 1    | 90       | 90             | 0        |         | -         |               | -         |
| .02   | Weight Room                                   | 1    | 2,100    | 2,100          | 1        | 30      | 30        | 83%           | 25        |
|   | a. Office                                     | 1    | 120      | 120            | 0        |         | -         |               | -         |
| .03   | Wrestling Room                                | 1    | 1,950    | 1,950          | 0        |         | -         |               | -         |
| .04   | Electrical Room                               | 1    |          | 0              | 0        |         | -         |               | -         |
| .05   | T.R. Room                                     | 2    | 200      | 400            | 0        |         | -         |               | -         |
|   |   |      |          | <b>8,070</b>   | <b>3</b> |         | <b>90</b> |               | <b>75</b> |

| <b>3.6 Outside Rooms</b> |                                   | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|--------------------------|-----------------------------------|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01                      | Ticket Booth                      | 0    | 0        | -              | 0        |         | -        |               | -        |
|                          | a. Concession Stand               | 1    | 600      | 600            | 0        |         | -        |               | -        |
|                          | b. Storage                        | 1    | 290      | 290            | 0        |         | -        |               | -        |
|                          | c. General Use Restroom           | 1    |          | 0              | 0        |         | -        |               | -        |
|                          | d. Custodial Storage              | 1    | 125      | 125            | 0        |         | -        |               | -        |
|                          | e. Turf Maintenance               | 1    | 600      | 600            | 0        |         | -        |               | -        |
| .02                      | Football/ Track Equipment Storage | 1    | 285      | 285            | 0        |         | -        |               | -        |
| .03                      | T.R. Room                         | 1    | 200      | 200            | 0        |         | -        |               | -        |
| .04                      | P.E./General Purpose Area         | 1    |          | 0              | 0        |         | -        |               | -        |
| .05                      | Football/Track                    | 1    |          | 0              | 0        |         | -        |               | -        |
| .06                      | Soccer Field                      | 1    |          | 0              | 0        |         | -        |               | -        |
| .07                      | Baseball Field                    | 1    |          | 0              | 0        |         | -        |               | -        |
| .08                      | Softball Field                    | 1    |          | 0              | 0        |         | -        |               | -        |
| .09                      | Concession Stand                  | 1    | 300      | 300            | 0        |         | -        |               | -        |
|                          | a. General Use Restroom           | 1    |          | 0              | 0        |         | -        |               | -        |
| .10                      | Basketball Courts                 | 6    |          | 0              | 0        |         | -        |               | -        |
| .11                      | Tennis Courts                     | 8    |          | 0              | 0        |         | -        |               | -        |
| .12                      | Future Portables (12 classrooms)  | 6    |          | 0              | 0        |         | -        |               | -        |
|                          |                                   |      |          | <b>2,400</b>   | <b>0</b> |         | <b>0</b> |               | <b>0</b> |


# PHYSICAL EDUCATION CENTER

## 3.0 PHYSICAL EDUCATION CENTER

### 3.1 Athletic Administration Area




### 3.2 Gymnasium Area




### 3.3 Girl's Locker Area




### 3.4 Boy's Locker Area




### 3.5 Exercise, Weight, and Wrestling Rooms



### 3.6 Outside Rooms



# ROOM DATA SHEETS



## DESCRIPTION

Relate to main gym/lobby entrance.  
 Windows with blinds for student observation and supervision at the main gym entrance doors preferred. Limited student traffic.  
 One 4' x 4' wall-mounted marker board.  
 Data ports per current CCSD standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. Quadraplex outlet to support each data port. One duplex outlet for each computer modem.  
 One clock / intercom.

## SERVICES

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No


## CRITERIA

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Aluminum with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

## KEY

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM



## DESCRIPTION

Relate to main gym/lobby entrance.  
 Windows with blinds for student observation and supervision at the main gym entrance doors preferred.  
 Door security.  
 Room motion Sensor.  
 Provide security camera termination board.  
 One 4' x 4' wall-mounted tackboard.  
 Data outlet per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 Quadraplex outlets to support each data port.  
 One duplex outlet on each remaining wall.  
 One ITV outlet, One CTV outlet.  
 One clock / intercom 72" A.F.F. with call button 48" A.F.F.

## SERVICES

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

## FINISHES

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 51  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

## KEY

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

### 3.1.01 | ATHLETIC DIRECTOR OFFICE


SCALE: 1/4" = 1'-0"

120 SF

### 3.1.02 | SECURITY/POLICE CAMPUS MONITOR

SCALE: 1/4" = 1'-0"

170 SF



**DESCRIPTION**

Relate to student parking lot for spectator access.  
 Exterior lighting. Main public entrance.  
 Built-in trophy case approximately 10' High x 12' wide.  
 Duplex outlets per code.  
 Two sets of drinking fountains near rest rooms.

**SERVICES**

HVAC Room Noise Criteria (dBA): -  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: -  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Storefront  
 STC Rating: -

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⊐ CLOCK/INTERCOM

**3.2.01 | GYMNASIUM LOBBY**

SCALE: 1/16" = 1'-0"

1,995 SF



**DESCRIPTION**

Two 8' wide food sales openings with lockable roll-up covers.  
 Built-in counter under the food sales openings with under counter storage with above counter duplex outlets located on each end and center of counter.  
 Built-in counter on back wall with two double sinks with hot and cold water, undercounter storage, and abovecounter electrical outlets 12" o.c.  
 Two duplex outlets on each remaining wall.  
 One abovecounter data outlet per premise wiring matrix. Door security.  
 Electrical not to be daisy-chained.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v + 210V (2) Freezers  
 Data: Yes  
 AV: No

**FINISHES**

Floor: Sealed concrete  
 Walls: Paint  
 STC Rating: -  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: -  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⊐ CLOCK/INTERCOM

**3.2.01A | CONCESSION BOOTH**

SCALE: 3/16" = 1'-0"

310 SF



**DESCRIPTION**

Student store lines should not interfere with gym lobby traffic flow. Provide roll-up fire shutter for serving counter to secure the area. Direct access from student activity center and main gym. One 4' x 4' wall-mounted tackboard. One 4' x 4' x 1' lockable glass display cabinet visible to student activity center. Lockable shutter with counter 2'10" A.F.F., approximately 1' either side of the window for purchases with electrical outlets for cash register. Lockable banker's drawer under sliding window's counter near cash register. One data port near customer serving window per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. Built-in counter on one wall 34" A.F.F., 24" deep, with H. C. sink with hot/cold water, abovecounter electrical plugmold and lockable undercounter storage. Area and power for 21 cu. ft. refrigerator/freezer. Three quadruplex or duplex outlets on each remaining wall. One clock / intercom. Electrical not to be daisy-chained.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v + 110v Freezer  
 Data: Yes  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**3.2.01B | STUDENT STORE**

230 SF

SCALE: 3/16" = 1'-0"



**DESCRIPTION**

Storage for sale items. 3 walls with built in storage shelving 24" deep 3 shelves high..

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM


**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**3.2.01C | STORAGE**

80 SF

SCALE: 1/4" = 1'-0"



**DESCRIPTION**

Provide gym smoke and fire beam detectors with quantities per code or a minimum of (4). Assistive listening system for hearing impaired. Infra red in conjunction with the P.A. system to accommodate a minimum of (8) receivers or meet code. Furnish and install gymnasium only P.A. system with plug-in jack on both sides and both ends of the main court. Provide seating for 1,350 persons. Seating should be retractable, manual and affixed to the walls that run parallel to the main basketball court. Main basketball court to be 50' x 84' with a 10' safety zone between end lines and the outer walls. 10' of unobstructed space along the length of the court is preferred. Furnish and install two shock absorbing goals with rectangular glass backboards (6' x 42") with slam dunk rims in the main court. Furnish and install four shock absorbing goals with rectangular glass backboards (6' x 42") with double ring rims with nylon net for the two parallel courts. All goals should be retractable. (See CCSD Purchasing Office for current Standards.) Furnish and install goal and end wall padding. Furnish and install volleyball system standards, padding, and floor plate/sleeves in each basketball court (3). Furnish and install (2) wall-mounted multi-sport scoreboards; one located on each end wall (end-of-period horn in place of buzzer), with plug-in outlet on both sides and both ends of the main court. A minimum of two duplex outlets on each end wall or to meet code. One duplex outlet on both sides of gym, centered at the top of the bleachers to accommodate filming of events in the gym. One ITV/CTV outlet on opposite ends for each side of the roll-up bleachers. Data outlets on both sides of the main court at center location with seating extended with power adjacent. Data outlet on both sides of the main court at center location with seating extended. Two clocks/intercoms on each end of the side basketball courts with protective wire cages (place them in the four corners of the gym). Easy access to gym lobby, drinking fountains and drinking fountains/cuspidors at entrance to Gym. Paint logo on gym floor. (Logo drawing to be supplied by school prior to final floor finish. #2 or better hardwood floor (oil base finish).

**FINISHES**

|             |                 |
|-------------|-----------------|
| Floor:      | Hardwood        |
| Walls:      | Paint           |
| STC Rating: | 51              |
| Ceiling:    | Open            |
| Height:     | 30'-0" min.     |
| CAC Rating: | 40              |
| Doors:      | Solid core wood |
| STC Rating: | 51              |

Note: Use Acoustical Engineer for all spaces

**KEY**

|  |                          |  |                |
|--|--------------------------|--|----------------|
|  | RECEPTACLE               |  | DATA           |
|  | QUAD RECEPTACLE          |  | TV OUTLET      |
|  | DATA/PHONE               |  | CLOCK/INTERCOM |
|  | FLOOR BOX (POWER & DATA) |  |                |


**SERVICES**

|                                 |      |
|---------------------------------|------|
| HVAC Room Noise Criteria (dBA): | 35   |
| Plumbing:                       | No   |
| Power:                          | 110v |
| Data:                           | Yes  |
| AV:                             | Yes  |

**3.2.02 | GYMNASIUM**

SCALE: 1/32" = 1'-0"

19,425 SF



**DESCRIPTION**

Easy access from exercise room.  
Storage of exercise equipment and supplies.  
One duplex outlet on each wall.

**FINISHES**

|             |                 |
|-------------|-----------------|
| Floor:      | VCT             |
| Walls:      | Paint           |
| STC Rating: | 51              |
| Ceiling:    | ACT             |
| Height:     | 9'-0" min.      |
| CAC Rating: | 40              |
| Doors:      | Solid core wood |
| STC Rating: | 51              |

Note: Use Acoustical Engineer for all spaces

**SERVICES**

|                                 |      |
|---------------------------------|------|
| HVAC Room Noise Criteria (dBA): | 35   |
| Plumbing:                       | No   |
| Power:                          | 110v |
| Data:                           | No   |
| AV:                             | No   |

**KEY**


|  |                          |  |                |
|--|--------------------------|--|----------------|
|  | RECEPTACLE               |  | DATA           |
|  | QUAD RECEPTACLE          |  | TV OUTLET      |
|  | DATA/PHONE               |  | CLOCK/INTERCOM |
|  | FLOOR BOX (POWER & DATA) |  |                |

**3.2.03, 3.2.04 |**

**WOMEN AND MEN TEAM STORAGE ROOM**

SCALE: 3/16" = 1'-0"

370 SF



**DESCRIPTION**

Direct access to main gym floor.  
 One 4' x 4' wall-mounted tackboard.  
 One 4' x 4' wall-mounted markerboard just inside the door.  
 One Duplex outlet on each wall.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51


Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**3.2.05 | PERFORMING GRP. STOR. & MEETING RM.** SCALE: 3/16" = 1'-0"

280 SF



**DESCRIPTION**

Easy access from girls locker rooms and boys locker rooms.  
 50'x 84' basketball court with 7' to 10' safety zone between end lines and the outer walls and the spectator sideline.  
 5' safety zone between the side line and the non-spectator wall.  
 Provide seating for 150 persons.  
 Seating should be fixed on one wall and run parallel to the basketball floor.  
 Provide P.A. system wall mounted plug in outlet.  
 Furnish and install two retractable shock absorbing goals with rectangular glass backboards (6' x 42") with slam dunk rims with goal and end wall padding.  
 Furnish and install volleyball floor plate/sleeves for one court.  
 One wall-mounted (side wall) multi-sport scoreboard on non-spectator side of court with plug-in outlet on spectator side of court.  
 Duplex outlets on gym walls per code.  
 Two ITV outlets.  
 One clock/intercom with call button 48" A.F.F. with wire guard.  
 (1) drinking fountain and (1) cuspidor in one corner of auxiliary gym with easy access from wrestling room (3.5.03).  
 #2 hardwood floor or better (oil base finish).  
 Drinking fountains to be located in the vicinity of the gym, not located within the hardwood flooring.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

**FINISHES**

Floor: Hardwood  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Open  
 Height: 30'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51  
 Hardware: Classroom lock


Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**3.2.06 | AUXILARY GYMNASIUM** SCALE: 1/16" = 1'-0"

6,930 SF



**DESCRIPTION**

Direct access to auxiliary gym (3.2.06).  
 Gymnasium Storage Storage of gymnastic and physical education equipment.  
 Two duplex outlets.

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51


Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM



**DESCRIPTION**

Storage area for janitor supplies. Includes mop sink. Relates to locker rooms and gymnasiums using a main hallway for access. Two duplex outlets. Vinyl tile floor.

**CRITERIA**

Floor: VCT  
 Walls: Paint  
 STC Rating: -  
 Ceiling: ACT  
 Height: 8'-0" min.  
 CAC Rating: 40  
 Doors: Solid Core Wood  
 STC Rating: -

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): -  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**3.2.06A | AUXILARY GYMNASIUM STORAGE**

SCALE: 3/16" = 1'-0"


270 SF

**3.2.07 | CUSTODIAL STORAGE ROOM**

SCALE: 3/16" = 1'-0"

150 SF





**DESCRIPTION**

Direct access from varsity team room (3.45).  
 Storage of football equipment.  
 One wall of lockable closet with shelf for football pants and pipe rack for hanging jerseys (at least 16').  
 Two duplex outlets near entrance.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No


**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM



**DESCRIPTION**

Relate to main gym aux gym and outdoor fields for access. Direct access to shower and rest room areas.  
 Visual supervision down locker rows from the P.E. Staff Office.  
 Excellent lighting.  
 One 4' x 8' wall-mounted tackboard located at the entrance to the locker area.  
 One 4' x 8' wall-mounted tackboard located at the front of the locker room near the varsity team room.  
 A minimum of (387) 12" wide x 16" deep x 40" high (3-tier) athletic lockers with a 4" curb (equals 1,161).  
 Fixed benches between locker rows.  
 (3) duplex outlets.  
 One ITV outlet.  
 One clock/intercom (no call button).  
 One (3) bubbler and one (2) bubbler non-refrigerated drinking fountains.  
 Floor drains for flood cleaning.  
 Provide ADA bench(s).

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**FINISHES**

Floor: Epoxy resin  
 Walls: Paint / tile  
 STC Rating: 51  
 Ceiling: Gypsum board  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

3.2.09 | EQUIPMENT STORAGE (FOOTBALL)

SCALE: 1/8" = 1'-0"


420 SF

3.3.01, 3.4.01 |

GIRLS' AND BOYS' LOCKER AREA

SCALE: 3/32" = 1'-0"

3,100 SF



**DESCRIPTION**

Access from locker rooms. Water closet and lavatory to meet code. ADA accessible shower in one stall. Shatterproof mirror. One GFIC duplex outlet near lavatory. Liquid soap dispenser. Paper towel dispenser. Roll toilet paper dispenser. Sanitary napkin dispenser/disposal.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

**FINISHES**

Floor: Epoxy resin  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Gypsum board  
 Height: 9'-0" min.  
 CAC Rating: 51  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**


- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- Ⓛ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

SCALE: 1/4" = 1'-0"

3.3.02, 3.4.02

SHOWER / GENERAL RESTROOM

120 SF (SHOWER ONLY)



**DESCRIPTION**

Direct access from locker room.  
 Easy access to staff office.  
 7' shelf with under shelf pipe rack for hanging uniforms.  
 Electrical for commercial washer (440v-480v) 3 phase, 2.8 amps) and dryer 480v, 3 phase, 38 amps).  
 Ventilation for dryer.  
 Washer and dryer are (OFOI) (install plumbing and electrical to support washer right/dryer left as you face them thus ensuring correct swing of the doors).  
 Floor drain.  
 One clock/intercom.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 480v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: Sealed Concrete  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51  
 Hardware: Classroom lock

Note Use Acoustical Engineer for all spaces

**KEY**


- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- Ⓛ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

SCALE: 1/4" = 1'-0"

3.3.03 , 3.4.03

WASHER / DRYER ROOM

140 SF



**DESCRIPTION**

Access to locker room. Easy access to shower area and restroom  
 Area for taping, first aid, and training table.  
 One 4' x 4' wall-mounted tackboard. one 4' x 4' wall-mounted marker board. (75) 12" wide x 16" deep x 72" high single tier full vented varsity lockers.  
 Sink with hot and cold water.  
 Two duplex outlets minimum. One ITV outlet on non-locker wall. One phone outlet and one clock/intercom with call button 48" A.F.F near entrance.  
 One clock/intercom.  
 Power connections not to be daisy-chained.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: Epoxy resin  
 Walls: Painted enamel  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**


- RECEPTACLE
- QUAD RECEPTACLE
- DATA/PHONE
- FLOOR BOX (POWER & DATA)
- DATA
- TV OUTLET
- CLOCK/INTERCOM

SCALE: 1/8" = 1'-0"

3.3.05, 3.4.05

**VARSITY TEAM / FIRST AID ROOM**

735 SF



**DESCRIPTION**

Easy access from locker room (3.3.05)  
 Storage Rooms relate to hallway for access.  
 Storage of athletic supplies and equipment.  
 One duplex outlet each room.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**FINISHES**

Floor: Sealed concrete  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**


- RECEPTACLE
- QUAD RECEPTACLE
- DATA/PHONE
- FLOOR BOX (POWER & DATA)
- DATA
- TV OUTLET
- CLOCK/INTERCOM

SCALE: 1/4" = 1'-0"

3.3.06, 3.4.06

**TEAM STORAGE ROOM**

90 SF



**DESCRIPTION**

Teaching/coaching office.  
 Visual supervision of locker room. Fixed glass windows. Sight lines down locker rows. One 4' x 8' wall-mounted tackboard. One 4' x 8' wall-mounted marker board.  
 Three data ports located on three walls. Quadraplex outlets to support each data port. One duplex outlet on each wall near data ports.  
 One ITV outlet. One CTV outlet.  
 One clock/intercom with call button 48" A.F.F.  
 Direct access to staff locker/shower room.

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Notes: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- Ⓛ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- Ⓛ CLOCK/INTERCOM


**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

SCALE: 3/16" = 1'-0"

3.3.07, 3.4.07 | **WOMEN AND MEN PE STAFF OFFICE**

450 SF



**DESCRIPTION**

Direct access from staff office  
 One shower with one shower head.  
 (7) 12" wide x 16" deep x 72" high athletic lockers (single tier).  
 Fixed bench along front of lockers.  
 One duplex outlet.  
 Shatterproof mirror(s).

**FINISHES**

Floor: Epoxy resin  
 Walls: Ceramic tile  
 STC Rating: 51  
 Ceiling: Gypsum board  
 Height: 9'-0" min.  
 CAC Rating: 51  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- Ⓛ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- Ⓛ CLOCK/INTERCOM


**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

SCALE: 1/4" = 1'-0"

3.3.07A, 3.4.07A | **STAFF LOCKER/SHOWER ROOM**

100 SF



**DESCRIPTION**

Gym hallway access.  
 Relate to both boys' and girls' student access from Gym.  
 Easy access to drinking fountain in the Gym.  
 15 air exchanges per hour.  
 One 4' x 8' wall-mounted tackboard near entrance.  
 One 4' x 8' wall-mounted maker board.  
 Two 4' x 8' shatterproof mirrors.  
 Three duplex outlets on each wall.  
 One ITV outlet.  
 One data outlet(VOIP) 48" A.F.F. near the gym entrance door.  
 One clock/intercom with call button 48" A.F.F. near entrance door.  
 Interactive flat panel with data/power and required backing.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes


**FINISHES**

Floor: Athletic flooring  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 15'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⊖ CLOCK/INTERCOM



**DESCRIPTION**

Easy access from exercise room.  
 Storage of exercise equipment and supplies.  
 One duplex outlet on each wall.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ⊖ CLOCK/INTERCOM

**3.5.01 | EXERCISE ROOM / FUNCTIONAL FITNESS / WELLNESS**


SCALE: 1/8" = 1'-0"

1,705 SF

**3.5.01A | STORAGE ROOM**

SCALE: 1/4" = 1'-0"

90 SF



**DESCRIPTION**

Outside and Gym access.  
 Relate to both boys' and girls' student access from Gym.  
 Easy access to drinking fountain in the Gym.  
 15 air exchanges per hour.  
 Walls should accommodate attachment of weight equipment.  
 One 4' x 8' wall-mounted tackboard near entrance.  
 One 4' x 8' wall-mounted marker board.  
 Two 4' x 8' shatterproof mirrors.  
 Three duplex outlets on each wall.  
 One ITV outlet.  
 Data outlet(VOIP) 48" A.F.F. near the gym entrance door.  
 One clock/intercom with call button 48" A.F.F. near the gym entrance door.  
 Weight room flooring (possibly athletic sheet flooring or any future increased technology type of flooring).

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes


**FINISHES**

Floor: Athletic sheet flooring  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 15'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM



**DESCRIPTION**

Direct access from weight room.  
 One 4' x 4' wall-mounted tack board.  
 One 4' x 4' wall-mounted marker board.  
 Quadraplex outlets to support each data port.  
 Two additional dplex outlets each wall near data ports.  
 One ITV outlet. One CTV outlet.  
 One clock intercom with call button 48" A.F.F.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: No

**CRITERIA**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**3.5.02 | WEIGHT ROOM**


2,100 SF

SCALE: 1/8" = 1'-0"

**3.5.02A | OFFICE**

120 SF

SCALE: 3/16" = 1'-0"



**DESCRIPTION**

Easy access to main gym and auxiliary gym  
 Access from boys area corridor.  
 Relate to boys' locker side of gym.  
 Easy access to (1) HCP drinking fountain and (1) cuspidor in the auxiliary gym  
 Room to accommodate (1) 42' x 42' wrestling mat with walk space down two sides.  
 Individual temperature control.  
 15 air exchanges per hour.  
 One 4' x 8' wall-mounted tackboard near the entrance.  
 Two 4' x 8' shatterproof mirrors.  
 Nine duplex outlets (3 each on 3 walls).  
 One ITV outlet.  
 One clock / intercom with call button 48" A.F.F.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 12'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**3.5.03 | WRESTLING ROOM**

SCALE: 3/32" = 1'-0"

1,950 SF



**DESCRIPTION**

Exterior lighting on all sides. Access to football field.  
 One outside (3) bubbler drinking fountain.  
 Outside access door.  
 Two 8' wide food sales openings with lockable roll-up covers.  
 Built-in counter with undercounter storage and abovecounter duplex outlets located on each end and center of counter.  
 Built-in counter on back wall with two double sinks with hot and cold water, undercounter storage, and abovecounter electrical plugmold.  
 Two duplex outlets on each remaining wall.  
 Electrical not to be daisy-chained.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: Yes

**CRITERIA**

Floor: Sealed concrete floor  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Hollow metal  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**3.6.01A | CONCESSION STAND**

SCALE: 1/8" = 1'-0"

600 SF



**DESCRIPTION**

Access to football field. Exterior lighting.  
 Outside drinking fountains. Outside access door.  
 Two duplex outlets.  
 Door security.

**FINISHES**

Floor: Sealed concrete  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Hollow metal  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No


**KEY**

- ⊕ RECEPTACLE                      ▷ DATA
- ⊕ QUAD RECEPTACLE            ▶ TV OUTLET
- ▶ DATA/PHONE                      □ CLOCK/INTERCOM
- ⊕ FLOOR BOX (POWER & DATA)

**3.6.01B | STORAGE**

SCALE: 3/16" = 1'-0"

290 SF



**DESCRIPTION**

Custodial storage with mop sink. Three duplex outlets plus power panels for the building. Door security. Sealed concrete floor.

**FINISHES**

Floor: Sealed Concrete  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Open  
 Height:                      CAC Rating: 40  
 Doors: Hollow Metal  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

**KEY**


- ⊕ RECEPTACLE                      ▷ DATA
- ⊕ QUAD RECEPTACLE            ▶ TV OUTLET
- ▶ DATA/PHONE                      □ CLOCK/INTERCOM
- ⊕ FLOOR BOX (POWER & DATA)

**3.6.01D | CUSTODIAL STORAGE**

SCALE: 1/4" = 1'-0"

125 SF





**DESCRIPTION**

Storage for turf maintenance tools and equipment.  
 Roll up door to be accessible for heavy equipment.  
 One duplex outlet one each wall.  
 Door secure from theft and vandalism.

**FINISHES**

Floor: Sealed concrete  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Open  
 Height: -  
 Doors: Hollow metal  
 STC Rating: 51


Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM



**DESCRIPTION**

Direct access from varsity team room.  
 Storage of football equipment.  
 One wall of lockable closet with shelf for football pants and pipe rack for hanging jerseys (at least 16').  
 Two duplex outlets near entrance.  
 Vinyl tile floor.

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Open  
 Height: -  
 CAC Rating: 40  
 Doors: Hollow metal  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**3.6.01E | TURF MAINTENANCE**


600 SF

SCALE: 1/8" = 1'-0"

**3.6.02 | FOOTBALL/TRACK EQUIPMENT STORAGE**

285 SF

SCALE: 3/16" = 1'-0"



**DESCRIPTION**

Exterior lighting on all sides. Access to Soccer/Baseball/Softball fields.  
 One outside (3) bubbler drinking fountain.  
 Outside access door.  
 Two 8' wide food sales openings with lockable roll-up covers.  
 Built-in counter with undercounter storage and abovecounter duplex outlets located on each end and center of counter.  
 Built-in counter on back wall with two double sinks with hot and cold water, undercounter storage, and abovecounter electrical plugmold.  
 Two duplex outlets on each remaining wall.

**CRITERIA**

Floor: Sealed concrete floor  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Hollow metal  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: No

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**3.6.09 | CONCESSION STAND**

300 SF

# **04 STUDENT ACTIVITY CENTER / MAINTENANCE & OPERATIONS CENTER**

# STUDENT ACTIVITY CENTER / MAINTENANCE & OPERATIONS CENTER

|            |  |               |          |          |          |
|------------|--|---------------|----------|----------|----------|
| <b>4.0</b> | <b>STUDENT ACTIVITY CENTER / MAINTENANCE &amp; OPERATIONS CENTER</b> | <b>24,440</b> | <b>0</b> | <b>0</b> | <b>0</b> |
|------------|--|---------------|----------|----------|----------|

| <b>4.1</b> | <b>Commons Area / Student Activity Cen</b> | Qty. | Net Area | Total Net Area | Teaching #T.S. | # Stud. | Capacity @ 100% | Utilization % | Functional Capacity |
|------------|--|------|----------|----------------|----------------|---------|-----------------|---------------|---------------------|
| .01        | Commons Area - Interior Plaza              | 1    | 6,755    | 6,755          | 0              |         | -               |               | -                   |
| .02        | Student Activity Center                    | 1    | 8,140    | 8,140          | 0              |         | -               |               | -                   |
|            | a. Custodial Storage                       | 1    | 100      | 100            | 0              |         | -               |               | -                   |
|            | b. Equipment Storage room                  | 1    | 405      | 405            | 0              |         | -               |               | -                   |
| .03        | Student Government Room                    | 1    | 250      | 250            | 0              |         | -               |               | -                   |
| .04        | TR Room                                    | 1    | 200      | 200            | 0              |         | -               |               | -                   |
| .05        | Faculty Break Room                         | 1    | 700      | 700            | 0              |         | -               |               | -                   |
| .06        | Outside Patio Area                         | 1    |          | 0              | 0              |         | -               |               | -                   |
| .07        | Staff General Use Restroom                 | 1    |          | 0              | 0              |         | -               |               | -                   |
|            |  |      |          | <b>16,550</b>  | <b>0</b>       |         | <b>0</b>        |               | <b>0</b>            |

| <b>4.2</b> | <b>Cafeteria Area</b>       | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|------------|-----------------------------|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01        | Food Serving Area           | 1    | 990      | 990            | 0        |         | -        |               | -        |
| .02        | Kitchen Prep Area           | 1    | 1,970    | 1,970          | 0        |         | -        |               | -        |
|            | a. Pot Washing              | 1    | 240      | 240            | 0        |         | -        |               | -        |
|            | b. Walk-in Refrigerator     | 1    | 260      | 260            | 0        |         | -        |               | -        |
|            | c. Walk-in Freezer          | 1    | 260      | 260            | 0        |         | -        |               | -        |
|            | d. General and Dry Storage  | 1    | 245      | 245            | 0        |         | -        |               | -        |
| .03        | Office                      | 1    | 120      | 120            | 0        |         | -        |               | -        |
| .04        | Cafeteria Staff Locker Room | 1    | 120      | 120            | 0        |         | -        |               | -        |
| .05        | Cafeteria Staff Restroom    | 1    |          | 0              | 0        |         | -        |               | -        |
|            |                             |      |          | <b>4,205</b>   | <b>0</b> |         | <b>0</b> |               | <b>0</b> |

| <b>4.3</b> | <b>Maintenance &amp; Operations Complex</b> | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|------------|---|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01        | General Workshop                            | 1    | 955      | 955            | 0        |         | -        |               | -        |
|            | a. Tool Storage Room                        | 1    | 140      | 140            | 0        |         | -        |               | -        |
| .02        | Office                                      | 1    | 120      | 120            | 0        |         | -        |               | -        |
|            | a. Staff Locker Area                        | 1    | 60       | 60             | 0        |         | -        |               | -        |
|            | b. Staff General Use Restroom               | 1    |          | 0              | 0        |         | -        |               | -        |
| .03        | Main Electrical Room                        | 1    | 420      | 420            | 0        |         | -        |               | -        |
| .04        | Emergency Electrical Room                   | 1    | 70       | 70             | 0        |         | -        |               | -        |
| .05        | Boiler Room                                 | 1    | 830      | 830            | 0        |         | -        |               | -        |
| .06        | Chiller Room                                | 1    | 1,090    | 1,090          | 0        |         | -        |               | -        |
| .07        | Mechanical Yard                             | 1    |          | 0              | 0        |         | -        |               | -        |
|            |   |      |          | <b>3,685</b>   | <b>0</b> |         | <b>0</b> |               | <b>0</b> |


# STUDENT ACTIVITY CENTER / MAINTENANCE & OPERATIONS CENTER

## 4.0 STUDENT ACTIVITY CENTER / MAINTENANCE & OPERATIONS CENTER


### 4.1 Commons Area / Student Activity Center




### 4.2 Cafeteria Area



### 4.3 Maintenance & Operations Complex



# ROOM DATA SHEETS



## DESCRIPTION

Student Activity Center with 528+ seats, plan for 1,000 students per lunch. Relate to commons area for direct access. Multipurpose area for student functions including dining, lounging, studying, testing and dancing. Two 4'x8' wall-mounted tackboards located just inside the main entrance doors. Presentation area with P.A. system, and electrical (100 and 200) to accommodate a dance band. Assitive listening system for hearing impaired. Infra red in conjunction with the P. A. system to accommodate a minimum of eight (8) receivers. Wall-mounted duplex outlet every 15 feet. Two ITV outlets. One CTV outlet. Three clock / intercoms with call buttons 48" A.F.F.

## SERVICES

HVAC Room Noise Criteria (dBA): 30  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: Yes


## CRITERIA

Floor: VCT  
 Walls: Paint  
 STC Rating: 79  
 Ceiling: ACT/Open  
 Height: Varies  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite /Storefront  
 STC Rating: 79

Note: Use Acoustical Engineer for all spaces

## KEY

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM



## DESCRIPTION

Custodial storage with mop sink with hot/cold water and mop rack, (include FRP wainscot on side walls that are drywall). One duplex outlet.

## SERVICES

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

## FINISHES

Floor: Sealed concrete  
 Walls: FRP/Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

## KEY

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

4.1.02 | STUDENT ACTIVITY CENTER

SCALE: 3/64" = 1'-0"


8,140 SF

4.1.02A, 7.2.06, 10.2.03,  
 11.2.06, 12.2.06

100 SF

SCALE: 3/8" = 1'-0"

CUSTODIAL STORAGE



**DESCRIPTION**

One duplex outlet on each wall.  
Access from student activity center.

**FINISHES**

Floor: VCT  
Walls: Paint  
STC Rating: 51  
Ceiling: ACT  
Height: 9'-0" min.  
CAC Rating: 40  
Doors: Solid core wood  
STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**4.1.02B | EQUIPMENT STORAGE ROOM**

SCALE: 3/16" = 1'-0"

405 SF



**DESCRIPTION**

Access from vestibule leading from student activity center.  
Student leader meetings. Two 4' x 4' wall-mounted marker boards.  
One data port per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. One quadruplex on each of two walls. One duplex outlet on each remaining wall. One ITV outlet.  
One clock / intercom with call button 48" A.F.F. near the entrance door.

**CRITERIA**

Floor: Carpet  
Walls: Paint  
STC Rating: 51  
Ceiling: ACT  
Height: 9'-0" min.  
CAC Rating: 40  
Doors: Solid core wood with vision lite  
STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM


**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
Plumbing: No  
Power: 110v  
Data: Yes  
AV: Yes

**4.1.03 | STUDENT GOVERNMENT ROOM**

SCALE: 3/16" = 1'-0"

250 SF



**DESCRIPTION**

Direct access served out of the kitchen. Isolate as much as possible from student traffic. One 4' x 8' wall-mounted tackboard. Built-in counter, 34" A.F.F., 24" deep, double sink with hot and cold water, disposal, abovecounter and undercounter storage, and three abovecounter duplex outlets for microwave, coffee pot, etc. Area and power for two large vending machines, stove/range (220v) with above stove space saver microwave with self contained range hood (CFI), and two refrigerators/freezers (21 cu. ft.). Contractor to provide power for space saver microwave. Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. Isobar surge protection for computer. Two duplex outlets on each wall minimum or to code. One ITV outlet mounted at 18" A.F.F. with support duplex outlet in one corner of the room. One CTV outlet mounted at 18" A.F.F. with support duplex outlet in one corner of the room. One clock / intercom with call button 48" A.F.F. One refrigerated drinking fountain with 36" to spout and one HCP refrigerated drinking fountain with handicap access and push action for water. Power not to be daisy chained.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v / 220v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**4.1.05 | FACULTY BREAK ROOM**

SCALE: 1/8" = 1'-0"

700 SF



**DESCRIPTION**

Area should include entrance and exit guidance into the food service serving area from student activity center as determined by the CCSD kitchen consultant. Two stainless steel mobile island counters with four cashier stations which can be used for serving or isolated from the kitchen prep area and locked off from the student activity when not in use. Computer networking conduit with cable at all cashier stations with connections back to the kitchen manager's office and then back to the central computer rack per matrix. Duplex outlets with surge protection to support computers at each cashier's station. Data outlet at each cashier station. Electrical and plumbing connections to the serving islands per kitchen consultant.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v/240v  
 Data: Yes  
 AV: No

**CRITERIA**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Coiling Grille  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**


- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**4.2.01 | FOOD SERVICING AREA**

SCALE: 1/8" = 1'-0"

990 SF





**DESCRIPTION**

Rectangular area for food preparation and serving of 1,000 students each in three shifts. Serving of dinners and banquets. Kitchen layout to be determined by CCSD kitchen consultant. Bug eradicator unit above service door at the kitchen area for energy conservation and insect control during delivery of food items. Bell ringer in kitchen wired to manager's office. Built-in counter, 32" A.F.F., 32" deep with change drawer and undercounter storage with lockable roll-up double window for faculty/staff food sales with two duplex outlets and one data outlet with data connectors back to the kitchen manager's office and the central computer rack. All shelving and cupboards in food service, kitchen prep and pot washing areas must be made of stainless steel. (No plastic laminate casework in kitchen area.) Electrical requirements will be provided by kitchen consultant. Water and power for ice machine (CFCI). HCP electric water cooler. Phone outlets if required by Food Services. One clock 72" A.F.F. Secure area.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v /240v  
 Data: Yes  
 AV: No


**CRITERIA**

Floor: Quarry tile  
 Walls: FRP  
 STC Rating: 51  
 Ceiling: Cleanable ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM



**DESCRIPTION**

Direct access from Kitchen Prep Area.  
 Open type door entry to room (no door).

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

**CRITERIA**

Floor: Quarry tile  
 Walls: FRP  
 STC Rating: 51  
 Ceiling: Cleanable ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

4.2.02 | KITCHEN PREP AREA


SCALE: 3/32" = 1'-0"

1,970 SF

4.2.02A | POT WASHING

SCALE: 3/16" = 1'-0"

240 SF



**DESCRIPTION**

Direct access to Kitchen Prep Area.  
 Refrigerator should be long and narrow with adjustable shelving and lockable door. 38 degree food storage.  
 Temperature malfunction alarm.  
 Insulated walls and refrigerator door per CCSD Food Service guidelines.  
 No interior electrical panels.

**CRITERIA**

Floor: Quarry tile  
 Walls: FRP  
 STC Rating: -  
 Ceiling: Open to deck  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: -


Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM



**DESCRIPTION**

Access through walk-in refrigerator.  
 Freezer should be long and narrow with adjustable shelving and lockable door. 0 degree food storage.  
 Temperature malfunction alarm.  
 Insulated walls and freezer door per CCSD Food Service guidelines.  
 No interior electrical panels.

**CRITERIA**

Floor: Quarry tile  
 Walls: FRP  
 STC Rating: -  
 Ceiling: Cleanable ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: -

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): -  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**4.2.02B | WALK-IN REFRIGERATOR**


SCALE: 3/16" = 1'-0"

260 SF

**4.2.02C | WALK-IN FREEZER**

SCALE: 3/16" = 1'-0"

260 SF



#### DESCRIPTION

Direct access to kitchen prep area.  
 Lockable door.  
 Rectangular or square area to allow adjustable shelving all around.  
 No interior electrical panels.  
 Provide plugmold on back wall with outlets to be located 12" O.C. for recharging equipment.  
 Power connections not to be daisy chained.

#### CRITERIA

Floor: Quarry tile  
 Walls: FRP  
 STC Rating: -  
 Ceiling: Cleanable ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: -


Note: Use Acoustical Engineer for all spaces

#### SERVICES

HVAC Room Noise Criteria (dBA): -  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

#### KEY

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM



#### DESCRIPTION

Direct access to kitchen prep area.  
 Visual supervision of kitchen preparation.  
 One 4' x 4' wall-mounted tackboard.  
 Floor safe (approximately 2 cu. ft. prefer rectangular and maximum 12" below floor level).  
 Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 One quadraplex outlet on each of two walls related to desk location and data ports.  
 One bell ringer for exterior delivery door.  
 One clock / intercom with call button near desk area.  
 Secure area.

#### CRITERIA

Floor: Quarry tile  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

#### SERVICES

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

#### KEY

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

## 4.2.02D | GENERAL AND DRY STORAGE


SCALE: 3/16" = 1'-0"

245 SF

## 4.2.03 | OFFICE

SCALE: 3/16" = 1'-0"

120 SF



**DESCRIPTION**

Direct access from kitchen prep. Accessible by kitchen staff. Support for seven full-time employees. Seven 12" wide x 16" deep x 60" high (double tier) athletic lockers (equals {14} 30" high lockers). One double prong clothes hook on back of entrance door. One clock / intercom near entrance door.

**CRITERIA**

|             |                                  |
|-------------|----------------------------------|
| Floor:      | Quarry tile                      |
| Walls:      | FRP                              |
| STC Rating: | 51                               |
| Ceiling:    | Cleanable ACT                    |
| Height:     | 9'-0" min.                       |
| CAC Rating: | 40                               |
| Doors:      | Solid core wood with vision lite |
| STC Rating: | 51                               |


Note: Use Acoustical Engineer for all spaces

**SERVICES**

|                                 |      |
|---------------------------------|------|
| HVAC Room Noise Criteria (dBA): | 45   |
| Plumbing:                       | No   |
| Power:                          | 110v |
| Data:                           | No   |
| AV:                             | No   |

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM



**DESCRIPTION**

Outside access with one 3' wide normal door, one 10' wide roll-up door, and one double door. Shop should be adjacent to the main school electrical, chiller, air compressor, and HVAC control/boiler room areas. Repair area with 16' long 36" A.F.F. work counter with abovecounter electrical plugmold and undercounter storage (must support 5"machinist's vise). Provide lockable tool storage cabinet. Duplex outlets every 20' on walls or as required by code. Power connections not to be daisy-chained. Deep sink with hot and cold water. One clock / intercom near the door.

**FINISHES**

|             |                                  |
|-------------|----------------------------------|
| Floor:      | Sealed concrete                  |
| Walls:      | Paint                            |
| STC Rating: | 51                               |
| Ceiling:    | ACT                              |
| Height:     | Open to deck                     |
| CAC Rating: | 40                               |
| Doors:      | Solid core wood with vision lite |
| STC Rating: | 51                               |

Note: Use Acoustical Engineer for all spaces

**SERVICES**

|                                 |      |
|---------------------------------|------|
| HVAC Room Noise Criteria (dBA): | 40   |
| Plumbing:                       | No   |
| Power:                          | 110v |
| Data:                           | Yes  |
| AV:                             | No   |

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

4.2.04 | CAFETERIA STAFF LOCKER ROOM


SCALE: 1/4" = 1'-0"

120 SF

4.3.01 | GENERAL WORKSHOP

SCALE: 1/8" = 1'-0"

955 SF



**DESCRIPTION**

Direct access from general workshop.  
One duplex outlet on three walls.

**FINISHES**

Floor: Sealed concrete  
Walls: Paint  
STC Rating: 51  
Ceiling: ACT  
Height: Open to deck  
CAC Rating: 40  
Doors: Solid core wood  
STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
Plumbing: No  
Power: 110v  
Data: No  
AV: No


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**4.3.01A | TOOL STORAGE ROOM**

140 SF

SCALE: 1/4" = 1'-0"



**DESCRIPTION**

Direct access from general workshop.  
Maintenance and operations office.  
One 4'x4' wall-mounted tackboard located near the entrance.  
Two data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. Quadraplex outlets near data ports. One duplex outlet on walls without the quadraplex outlets.  
One clock / intercom with call button 48" A.F.F.

**FINISHES**

Floor: VCT  
Walls: Paint  
STC Rating: 51  
Ceiling: ACT  
Height: 9'-0" min.  
CAC Rating: 40  
Doors: Solid core wood with vision lite  
STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
Plumbing: No  
Power: 110v  
Data: Yes  
AV: No


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**4.3.02 | OFFICE**

120 SF

SCALE: 1/4" = 1'-0"



**DESCRIPTION**

Direct access from general workshop. (12) 16" deep x 12" wide x 72" high single tier lockers.

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC: Yes  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- Ⓛ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

4.3.02A | STAFF LOCKER AREA

SCALE: 3/8" = 1'-0"

60 SF

# 05 ARTS ACADEMY / FLEX

# ARTS ACADEMY / FLEX

|            |                            |  |              |          |            |            |
|------------|----------------------------|--|--------------|----------|------------|------------|
| <b>5.0</b> | <b>ARTS ACADEMY / FLEX</b> |  | <b>7,285</b> | <b>4</b> | <b>120</b> | <b>100</b> |
|------------|----------------------------|--|--------------|----------|------------|------------|


| <b>5.1</b> | <b>Arts Center / Exterior Art Yard</b> | Qty. | Net Area | Total Net Area | Teaching #T.S. | # Stud. | Capacity @ 100% | Utilization % | Functional Capacity |
|------------|--|------|----------|----------------|----------------|---------|-----------------|---------------|---------------------|
| .01        | Art Classroom                          | 2    | 1,160    | 2,320          | 2              | 30      | 60              | 83%           | 50                  |
|            | a. Project Storage Rooms               | 1    | 290      | 290            | 0              |         | -               |               | -                   |
| .02        | Ceramics                               | 1    | 1,160    | 1,160          | 1              | 30      | 30              | 83%           | 25                  |
|            | a. Project Storage Rooms               | 1    | 335      | 335            | 0              |         | -               |               | -                   |
|            | b. Slip Room                           | 1    | 155      | 155            | 0              |         | -               |               | -                   |
|            | c. Kiln Room                           | 1    | 125      | 125            | 0              |         | -               |               | -                   |
|            | d. Art Yard                            | 1    |          | 0              | 0              |         | -               |               | -                   |
| .03        | Electrical/Mechanical Room             | 1    |          | 0              | 0              |         | -               |               | -                   |
|            |  |      |          | <b>4,385</b>   | <b>3</b>       |         | <b>90</b>       |               | <b>75</b>           |

| <b>5.2</b> | <b>Flex Room</b> | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%    | Utilization % | Capacity  |
|------------|------------------|------|----------|----------------|----------|---------|-----------|---------------|-----------|
| .01        | Flex Room        | 1    | 2,700    | 2,700          | 1        | 30      | 30        | 83%           | 25        |
|            |                  |      |          | <b>2,700</b>   | <b>1</b> |         | <b>30</b> |               | <b>25</b> |



## 5.0 CONSUMER SCIENCE CENTER / ARTS ACADEMY / LECTURE ROOM


### 5.1 Arts Center / Exterior Art Yard



### 5.2 Lecture Center



# ROOM DATA SHEETS



## DESCRIPTION


Outdoor access to the exterior art yard.  
 Area for (16) 36" wide x 72" long x 30" high rectangular tables.  
 Two 8' Uneek Visual Holders.  
 Two 4' x 4' wall-mounted tackboard near the entrance.  
 Two 4' x 8' wall-mounted marker boards located at the front of the classroom.  
 One built-in work counter with four 20" deep sinks and one 6' long double spigot trough sink, both sink types to include sediment traps, hot and cold water, gooseneck type fixtures with washable splash boards on the wall behind the sink area 30" high with undercounter storage.  
 Three abovecounter duplex outlets (not over sinks).  
 Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 Three power outlets with quadplex outlets related to data ports and additional power drops from ceiling.  
 One dedicated circuit 20 amp special purpose receptacle.  
 Provide power, data connections and wall blocking at interactive flat panel locations.  
 One clock / intercom with call button 48" A.F.F.  
 One 72" wide x 88" high x 14" deep two door cabinet with five adjustable shelves.

## FINISHES

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 20'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

## KEY




## SERVICES

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: Yes

## 5.1.01 | ART CLASSROOM

SCALE: 1/8" = 1'-0"

1,160 SF



## DESCRIPTION


Direct access from art classrooms.  
 Rooms Storage of student project.  
 Two duplex outlets.

## FINISHES

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

## KEY




## SERVICES

HVAC Room Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

## 5.1.01A | PROJECT STORAGE ROOMS

SCALE: 3/16" = 1'-0"

290 SF



**DESCRIPTION**


Outdoor access to the exterior art yard.  
 Windows (natural light) with blinds facing courtyard.  
 Area for (16) 36" wide x 72" long x 30" high rectangular tables, (1) kick wheel, and (3) electric wheels.  
 Two 8' Uneek Visual Holders.  
 Two 4' x 4' wall-mounted tackboards near the entrance.  
 Two 4' x 8' wall-mounted marker boards located at the front of the classroom.  
 One built-in work counter with four 20" deep sinks and one 6' long double spigot trough sink, both sink types to include sediment traps, hot and cold water, gooseneck type fixtures with washable splash boards on the wall behind the sink area 30" high with undercounter storage.  
 Three abovecounter duplex outlets (not over sinks).  
 Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 Three power outlets with quadraplex outlets related to data ports and additional duplex outlets on remaining walls.  
 Provide power, data connections and wall blocking at interactive flat panel locations.  
 One dedicated circuit 20 amp special purpose receptacle.  
 One clock / intercom with call button 48" A.F.F.  
 One 72" wide x 88" high x 14" deep two door cabinet with five adjustable shelves.

**CRITERIA**

|             |                                  |
|-------------|----------------------------------|
| Floor:      | VCT                              |
| Walls:      | Paint                            |
| STC Rating: | 51                               |
| Ceiling:    | ACT                              |
| Height:     | 12'-0" min.                      |
| CAC Rating: | 40                               |
| Doors:      | Solid core wood with vision lite |
| STC Rating: | 51                               |

Note: Use Acoustical Engineer for all spaces

**KEY**




**SERVICES**

|                                 |      |
|---------------------------------|------|
| HVAC Room Noise Criteria (dBA): | 35   |
| Plumbing:                       | Yes  |
| Power:                          | 110v |
| Data:                           | Yes  |
| AV:                             | Yes  |

**5.1.02 | CERAMICS CLASSROOM**

SCALE: 1/16" = 1'-0"

1,160 SF



**DESCRIPTION**

Direct access from Ceramics classroom.  
 Room Storage of textbooks, supplies, and student projects.  
 One duplex outlet.

**FINISHES**


|             |                                  |
|-------------|----------------------------------|
| Floor:      | VCT                              |
| Walls:      | Paint                            |
| STC Rating: | 51                               |
| Ceiling:    | ACT                              |
| Height:     | 9'-0" min.                       |
| CAC Rating: | 40                               |
| Doors:      | Solid core wood with vision lite |
| STC Rating: | 51                               |

Note: Use Acoustical Engineer for all spaces

**SERVICES**

|                                 |      |
|---------------------------------|------|
| HVAC Room Noise Criteria (dBA): | 35   |
| Plumbing:                       | No   |
| Power:                          | 110v |
| Data:                           | No   |
| AV:                             | No   |


**KEY**



**5.1.02A | PROJECT STORAGE ROOMS**

SCALE: 3/16" = 1'-0"

335 SF



**DESCRIPTION**

Direct access from Ceramics classroom.  
 Area for two 19" x 20" wedging tables.  
 One 9' counter with 20" deep sink, hot and cold water, with clay trap.  
 One duplex outlet over counter.  
 Four duplex outlets on other walls.

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**5.1.02B | SLIP ROOM**

155 SF

SCALE: 1/4" = 1'-0"



**DESCRIPTION**

Access from art classrooms and ceramics classroom.  
 Provide one electrical kiln and one gas kiln.  
 Gas kiln needs exhaust stack vented through the roof.  
 Appropriate venting and cover for the kilns are necessary.  
 Appropriate location spacing to meet local city fire department code/requirements interpretation.

**CRITERIA**

Floor: Sealed concrete  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 12'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v /240v, gas hookup  
 Data: No  
 AV: No


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**5.1.02C | KILN ROOM**

125 SF

SCALE: 3/16" = 1'-0"



**DESCRIPTION**

Divisible to two 1350 SF rooms.  
 Flexible seating.  
 Include a P.A. system with a plug-in outlet.  
 Two 4' x 8' wall-mounted tackboards and two 4' x 8' wall-mounted marker boards located at the front of the room, on each side of divisible space.  
 Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 Minimum of one quadruplex outlet on front wall.  
 One duplex outlet every 15' on walls.  
 Provide power, data connections and backing at interactive flat panel locations on each side of divisible space.  
 One clock intercom with call button 48" A.F.F. on each side of divisible space.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**5.2.01 | FLEX ROOM**

**2,700 SF**

SCALE: 3/32" = 1'-0"


# 06 VOCATIONAL TECHNOLOGIES

# VOCATIONAL TECHNOLOGIES

| <b>6.0 VOCATIONAL TECHNOLOGIES</b> |                         | <b>22,930</b> |          | <b>11</b>      |                | <b>330</b> |                 | <b>275</b>    |                     |
|------------------------------------|-------------------------|---------------|----------|----------------|----------------|------------|-----------------|---------------|---------------------|
| <b>6.1</b>                         | <b>CTE Program</b>      | Qty.          | Net Area | Total Net Area | Teaching #T.S. | # Stud.    | Capacity @ 100% | Utilization % | Functional Capacity |
| .01                                | CTE lab Type A          | 3             | 1,350    | 4,050          | 3              | 30         | 90              | 83%           | 75                  |
| .02                                | CTE lab Type B          | 6             | 1,800    | 10,800         | 6              | 30         | 180             | 83%           | 150                 |
| .03                                | CTE lab Type C          | 2             | 3,600    | 7,200          | 2              | 30         | 60              | 83%           | 50                  |
| .04                                | Distributed lab storage | 3             | 160      | 480            | 0              | -          | -               | -             | -                   |
| .05                                | T.R. Room               | 2             | 200      | 400            | 0              | -          | -               | -             | -                   |
|                                    |                         |               |          | <b>22,930</b>  | <b>11</b>      |            | <b>330</b>      |               | <b>275</b>          |


## 6.0 VOCATIONAL TECHNOLOGIES

### 6.1 CTE Program (Gia & Alaina)





# ROOM DATA SHEETS



## DESCRIPTION

Technology ready instruction with collaboration space - 3 classrooms. Ample power, data and AV ready. Floor boxes and/or overhead cord reel power. Two 4x8 tackboards and two 4x8 marker boards. Provide power, data connections and wall blocking at interactive flat panel locations. One clock / intercom with call button 48" A.F.F.

## POTENTIAL PROGRAMS

- |                               |                           |
|-------------------------------|---------------------------|
| Accounting & Finance          | Interior Design           |
| Administrative Services       | Law Enforcement           |
| Business Management           | Marketing                 |
| Community Health Service      | Mechanical Engineering    |
| Cosmetology                   | Military Science          |
| Criminal Justice              | Multimedia Communications |
| Early Childhood Education     | NAF Academy of Finance    |
| Fire Science                  | Photography               |
| Foods & Nutrition             | Radio Production          |
| Health Information Management | Respiratory Science       |
| High School of Business       | Teaching & Training       |
| Hospitality & Tourism         |                           |
| Hospitality & Tourism-NAF     |                           |

## SERVICES

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

## FINISHES

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


## KEY

- |  |                          |  |                |
|--|--------------------------|--|----------------|
|  | RECEPTACLE               |  | DATA           |
|  | QUAD RECEPTACLE          |  | TV OUTLET      |
|  | DATA/PHONE               |  | CLOCK/INTERCOM |
|  | FLOOR BOX (POWER & DATA) |  |                |

## 6.1.01 | CTE LAB TYPE A

SCALE: 1/8" = 1'-0"

1,350 SF



## DESCRIPTION

Technology ready instruction - heavy computer and media load - 6 classrooms. Ample power, data and AV ready. Floor boxes and/or overhead cord reel power. Provide sink with hot and cold water in two of the six classrooms. Two 4'x8' wall mounted tack boards and two 4'x8' marker boards. Provide power, data connections and wall blocking at interactive flat panel locations. One clock / intercom with call button 48" A.F.F.

## POTENTIAL PROGRAMS

- |                                   |                              |
|-----------------------------------|------------------------------|
| Aerospace Engineering             | Emergency Telecommunications |
| Animation                         | Fashion, Textiles & Design   |
| Architectural & Civil Engineering | Forensic Science             |
| Architectural Design              | Graphic Design               |
| Aviation Technology               | IT Networking/CISCO          |
| Baking & Pastry                   | Mechanical Engineering       |
| Biomedical                        | Medical Assisting            |
| Biomedical PLTW                   | Nursing Assistant            |
| Computer Science                  | Pharmacy Practice            |
| Culinary Arts                     | Plant Systems                |
| Cybersecurity                     | Sports Medicine              |
| Dental Science                    | Video Production             |
| Digital Game Development          | Web Design & Development     |
| Drafting & Design                 |                              |
| Electronic Technology             |                              |
| Emergency Medical Technician      |                              |

## FINISHES

Floor: VCT - Static dissipative  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

## KEY

- |  |                          |  |                |
|--|--------------------------|--|----------------|
|  | RECEPTACLE               |  | DATA           |
|  | QUAD RECEPTACLE          |  | TV OUTLET      |
|  | DATA/PHONE               |  | CLOCK/INTERCOM |
|  | FLOOR BOX (POWER & DATA) |  |                |


## SERVICES

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes/No  
 Power: 110v  
 Data: Yes  
 AV: Yes

## 6.1.02 | CTE LAB TYPE B

SCALE: 3/32" = 1'-0"

1,800 SF



**DESCRIPTION**

High bay space.  
 Provide sink with hot and cold water, emergency showers.  
 Two 4'x8' wall mounted tack boards and two 4'x8' marker boards.  
 Movable work stations on casters with ceiling mounted electrical outlets.  
 Provide power, data connections and wall blocking at interactive flat panel locations.  
 Ample power, data and AV ready for instructional tools and other equipment. Two air lines for pneumatic tools at work surface perimeter area. Work area with ceiling-mounted electrical and air outlets.  
 Connection for 220v/3/60 dust collection system on equipment wall.  
 One clock / intercom with call button 48" A.F.F.  
 Visual supervision of lab storage.

**POTENTIAL PROGRAMS**

- Agricultural Mechanics
- Technology
- Animal Systems
- Automotive Technology
- Aviation Maintenance Technician
- Construction Technology
- Furniture & Cabinetmaking
- Heating and Air Conditioning
- Industrial Maintenance
- Manufacturing Technologies
- Mechanical Technology
- Theatre Technology
- Welding Technology

**FINISHES**

Floor: Seamless epoxy flooring  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: Open  
 Height: 15'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM


**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v/220v/3 phase  
 Data: Yes  
 AV: Yes

**6.1.03 | CTE LAB TYPE C**

SCALE: 1/16" = 1'-0"

3,600 SF



**DESCRIPTION**

CTE storage buffers between labs, 3 rooms total.  
 Power for charging devices and three data port.

**FINISHES**

Floor: Sealed concrete  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**6.1.04 | DISTRIBUTED LAB STORAGE**

SCALE: 1/8" = 1'-0"

160 SF

# LEARNING COMMUNITIES

# LEARNING COMMUNITIES

## 7.0 LEARNING COMMUNITY - ONE 16,100 16 441 368

| 7.1 Administration |                            | Qty. | Net Area | Total Net Area | Teaching #T.S. | # Stud. | Capacity @ 100% | Utilization % | Functional Capacity |
|--------------------|----------------------------|------|----------|----------------|----------------|---------|-----------------|---------------|---------------------|
| .01                | Office                     | 2    | 120      | 240            | 0              |         | -               |               | -                   |
| .02                | Staff General Use Restroom | 1    |          | 0              | 0              |         | -               |               | -                   |
| .03                | Electrical Room            | 1    |          | 0              | 0              |         | -               |               | -                   |
| .04                | Teacher's Workroom         | 1    | 400      | 400            | 0              |         | -               |               | -                   |
| .05                | Conference Room            | 1    | 300      | 300            | 0              |         | -               |               | -                   |
|                    |                            |      |          | <b>940</b>     | <b>0</b>       |         | <b>0</b>        |               | <b>0</b>            |

| 7.2 Classrooms |                              | Qty. | Net Area | Total Net Area | #T.S.     | # Stud. | @ 100%     | Utilization % | Capacity   |
|----------------|------------------------------|------|----------|----------------|-----------|---------|------------|---------------|------------|
| .01            | Generic Classroom            | 13   | 900      | 11,700         | 13        | 30      | 390        | 83%           | 325        |
| .02            | Flex Lab / Classroom         | 1    | 1,800    | 1,800          | 1         | 30      | 30         | 83%           | 25         |
| .03            | Resource Classroom           | 1    | 600      | 600            | 1         | 12      | 12         | 83%           | 10         |
| .04            | Self-Contained               | 1    | 900      | 900            | 1         | 9       | 9          | 83%           | 8          |
|                | a. Restroom                  | 1    |          | 0              | 0         |         | -          |               | -          |
|                | b. Storage                   | 1    | 60       | 60             | 0         |         | -          |               | -          |
| .05            | Student General Use Restroom | 1    |          | 0              | 0         |         | -          |               | -          |
| .06            | Custodial Storage Room       | 1    | 100      | 100            | 0         |         | -          |               | -          |
| .07            | Fire Riser Room              | 1    |          | 0              | 0         |         | -          |               | -          |
|                |                              |      |          | <b>15,160</b>  | <b>16</b> |         | <b>441</b> |               | <b>368</b> |

## 8.0 LEARNING COMMUNITY - TWO 16,000 16 441 368

| 8.1 Administration |                    | Qty. | Net Area | Total Net Area | Teaching #T.S. | # Stud. | Capacity @ 100% | Utilization % | Functional Capacity |
|--------------------|--------------------|------|----------|----------------|----------------|---------|-----------------|---------------|---------------------|
| .01                | Office             | 2    | 120      | 240            | 0              |         | -               |               | -                   |
| .02                | Staff Restroom     | 1    |          | 0              | 0              |         | -               |               | -                   |
| .03                | Electrical Room    | 1    |          | 0              | 0              |         | -               |               | -                   |
| .04                | Teacher's Workroom | 1    | 400      | 400            | 0              |         | -               |               | -                   |
| .05                | Conference Room    | 1    | 300      | 300            | 0              |         | -               |               | -                   |
|                    |                    |      |          | <b>940</b>     | <b>0</b>       |         | <b>0</b>        |               | <b>0</b>            |

| 8.2 Classrooms |                       | Qty. | Net Area | Total Net Area | #T.S.     | # Stud. | @ 100%     | Utilization % | Capacity   |
|----------------|-----------------------|------|----------|----------------|-----------|---------|------------|---------------|------------|
| .01            | Generic Classroom     | 13   | 900      | 11,700         | 13        | 30      | 390        | 83%           | 325        |
| .02            | Flex Lab / Classroom  | 1    | 1,800    | 1,800          | 1         | 30      | 30         | 83%           | 25         |
| .03            | Resource Classroom    | 1    | 600      | 600            | 1         | 12      | 12         | 83%           | 10         |
| .04            | Self-Contained        | 1    | 900      | 900            | 1         | 9       | 9          | 83%           | 8          |
|                | a. Restroom           | 1    |          | 0              | 0         |         | -          |               | -          |
|                | b. Storage            | 1    | 60       | 60             | 0         |         | -          |               | -          |
| .05            | Student Restroom      | 1    |          | 0              | 0         |         | -          |               | -          |
| .06            | Elevator Machine Room | 1    |          | 0              | 0         |         | -          |               | -          |
| .07            | Elevators             | 2    |          | 0              | 0         |         | -          |               | -          |
|                |                       |      |          | <b>15,060</b>  | <b>16</b> |         | <b>441</b> |               | <b>368</b> |

# LEARNING COMMUNITIES

## 11.0 LEARNING COMMUNITY - THREE 15,300 15 393 328

| 11.1 | Administration     | Qty. | Net Area | Total Net Area | Teaching #T.S. | # Stud. | Capacity @ 100% | Utilization % | Functional Capacity |
|------|--------------------|------|----------|----------------|----------------|---------|-----------------|---------------|---------------------|
| .01  | Office             | 2    | 120      | 240            | 0              |         | -               |               | -                   |
| .02  | Staff Restroom     | 1    |          | 0              | 0              |         | -               |               | -                   |
| .03  | Electrical Room    | 1    |          | 0              | 0              |         | -               |               | -                   |
| .04  | T.R. Room          | 2    | 200      | 400            | 0              |         | -               |               | -                   |
| .05  | Teacher's Workroom | 1    | 400      | 400            | 0              |         | -               |               | -                   |
| .06  | Conference Room    | 1    | 300      | 300            | 0              |         | -               |               | -                   |
|      |                    |      |          | <b>1,340</b>   | <b>0</b>       |         | <b>0</b>        |               | <b>0</b>            |

| 11.2 | Classrooms             | Qty. | Net Area | Total Net Area | #T.S.     | # Stud. | @ 100%     | Utilization % | Capacity   |
|------|------------------------|------|----------|----------------|-----------|---------|------------|---------------|------------|
| .01  | Generic Classroom      | 11   | 900      | 9,900          | 11        | 30      | 330        | 83%           | 275        |
| .02  | Flex Lab / Classroom   | 1    | 1,800    | 1,800          | 1         | 30      | 30         | 83%           | 25         |
| .03  | Resource Classroom     | 2    | 600      | 1,200          | 2         | 12      | 24         | 83%           | 20         |
| .04  | Self-Contained         | 1    | 900      | 900            | 1         | 9       | 9          | 83%           | 8          |
|      | a. Restroom            | 1    |          | 0              | 0         |         | -          |               | -          |
|      | b. Storage             | 1    | 60       | 60             | 0         |         | -          |               | -          |
| .05  | Student Restroom       | 1    |          | 0              | 0         |         | -          |               | -          |
| .06  | Custodial Storage Room | 1    | 100      | 100            | 0         |         | -          |               | -          |
| .07  | Fire Riser Room        | 1    |          | 0              | 0         |         | -          |               | -          |
|      |                        |      |          | <b>13,960</b>  | <b>15</b> |         | <b>393</b> |               | <b>328</b> |

## 12.0 LEARNING COMMUNITY - FOUR 15,300 15 393 328


| 12.1 | Administration     | Qty. | Net Area | Total Net Area | Teaching #T.S. | # Stud. | Capacity @ 100% | Utilization % | Functional Capacity |
|------|--------------------|------|----------|----------------|----------------|---------|-----------------|---------------|---------------------|
| .01  | Office             | 2    | 120      | 240            | 0              |         | -               |               | -                   |
| .02  | Staff Restroom     | 1    |          | 0              | 0              |         | -               |               | -                   |
| .03  | Electrical Room    | 1    |          | 0              | 0              |         | -               |               | -                   |
| .04  | T.R. Room          | 2    | 200      | 400            | 0              |         | -               |               | -                   |
| .05  | Teacher's Workroom | 1    | 400      | 400            | 0              |         | -               |               | -                   |
| .06  | Conference Room    | 1    | 300      | 300            | 0              |         | -               |               | -                   |
|      |                    |      |          | <b>1,340</b>   | <b>0</b>       |         | <b>0</b>        |               | <b>0</b>            |

| 12.2 | Classrooms             | Qty. | Net Area | Total Net Area | #T.S.     | # Stud. | @ 100%     | Utilization % | Capacity   |
|------|------------------------|------|----------|----------------|-----------|---------|------------|---------------|------------|
| .01  | Generic Classroom      | 11   | 900      | 9,900          | 11        | 30      | 330        | 83%           | 275        |
| .02  | Flex Lab / Classroom   | 1    | 1,800    | 1,800          | 1         | 30      | 30         | 83%           | 25         |
| .03  | Resource Classroom     | 2    | 600      | 1,200          | 2         | 12      | 24         | 83%           | 20         |
| .04  | Self-Contained         | 1    | 900      | 900            | 1         | 9       | 9          | 83%           | 8          |
|      | a. Restroom            | 1    |          | 0              | 0         |         | -          |               | -          |
|      | b. Storage             | 1    | 60       | 60             | 0         |         | -          |               | -          |
| .05  | Student Restroom       | 1    |          | 0              | 0         |         | -          |               | -          |
| .06  | Custodial Storage Room | 1    | 100      | 100            | 0         |         | -          |               | -          |
| .07  | Elevators              | 2    |          | 0              | 0         |         | -          |               | -          |
|      |                        |      |          | <b>13,960</b>  | <b>15</b> |         | <b>393</b> |               | <b>328</b> |


# LEARNING COMMUNITIES

## 7.0 LEARNING COMMUNITY - ONE

### 7.1 Administration




### 7.2 Classrooms, Computer / Business Lab



## 8.0 LEARNING COMMUNITY - TWO

### 8.1 Administration



### 8.2 Classrooms



## 11.0 LEARNING COMMUNITY - THREE

### 11.1 Administration



### 11.2 Classrooms




## 12.0 LEARNING COMMUNITY - FOUR


### 12.1 Administration



### 12.2 Classrooms



# ROOM DATA SHEETS



## DESCRIPTION

One 4' x 4' wall-mounted tackboard near the entrance.  
 One data ports per current CCSD standard premise wiring matrix with conduit for computer networking with cable on each wall back to the central computer rack. Quadraplex outlets related to data ports and additional duplex outlets on each wall.  
 One ITV outlet. One CTV outlet.  
 One clock / intercom with call button 48" A.F.F.

## SERVICES

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

## FINISHES

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

## KEY


- RECEPTACLE
- QUAD RECEPTACLE
- DATA/PHONE
- FLOOR BOX (POWER & DATA)
- DATA
- TV OUTLET
- CLOCK/INTERCOM

SCALE: 1/4" = 1'-0"

## OFFICE

7.1.01, 8.1.01, 11.1.01, 12.1.01

120 SF



## DESCRIPTION

Teacher preparation area.  
 Designate one wall to provide and embed a display case visible to students in hallway 48" w x 88" h x 14" d with five adjustable shelves for student projects.  
 One 4' x 8' wall-mounted tackboard near the entrance above the counter.  
 One 10' built-in work counter with sink, hot/cold water, and under counter storage. Electrical for copy machine. Electrical not to be daisy-chained.  
 Six data ports per current CCSD standard premise wiring matrix with conduit for computer networking with cable on each wall back to the central computer rack. Quadraplex outlets related to data ports and additional duplex outlets on each wall.  
 Two floor mounted duplex outlets in each center half of room. One ITV outlet. One CTV outlet.  
 One clock / intercom with call button 48" A.F.F.

## SERVICES

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: No

## FINISHES

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

## KEY

- RECEPTACLE
- QUAD RECEPTACLE
- DATA/PHONE
- FLOOR BOX (POWER & DATA)
- DATA
- TV OUTLET
- CLOCK/INTERCOM



SCALE: 3/16" = 1'-0"

## TEACHER'S WORKROOM

7.1.04, 8.1.04, 11.1.05, 12.1.05

400 SF





**DESCRIPTION**

One 4' x 8' wall-mounted tackboard. One 4' x 8' wall-mounted marker board.  
 Provide power, data connections and wall blocking at interactive flat panel locations.  
 One data port on each of two side walls per current CCSD standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. One quadraplex outlet on each of two walls. One additional duplex outlet on each wall.  
 One clock / intercom located by the entrance door.  
 Sound attenuation and isolation.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

**CRITERIA**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

SCALE: 3/16" = 1'-0"

7.1.05, 8.1.05, 11.1.06, 12.1.06

**CONFERENCE ROOM**

300 SF

**DESCRIPTION**

General classroom instruction.  
 Two 4' x 8' wall-mounted tackboard, on a side wall near the entrance to the classroom.  
 Two 4' x 8' wall-mounted marker boards.  
 Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 Three power outlets with quadraplex outlets relating to data ports and duplex outlets spread equally on each wall.  
 Provide power, data connections and wall blocking at interactive flat panel locations.  
 One clock / intercom with call button 48" A.F.F.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

**CRITERIA**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM


SCALE: 1/8" = 1'-0"

7.2.01, 8.2.01,  
 11.2.01, 12.2.01

**GENERIC CLASSROOMS**

900 SF





**DESCRIPTION**

Divisible to two 900 SF rooms.  
 Flexible seating.  
 Teacher station and (30) Student stations on each side.  
 (9) Stations are to be wheelchair/hcp accessible/usable.  
 One 4' x 8' wall-mounted tackboard near the main entrance and two 4' x 8' marker boards located at the front of the classroom, on each side.  
 Power and data ports for (8) student printers per current CCSD standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 Three power outlets with quadraplex outlets related to data ports and additional duplex outlets on front and back walls.  
 Floor boxes with power and data for flexible work stations.  
 Provide power,data connections and wall blocking at interactive flat panel locations, on each side.  
 One clock / intercom with call button 48" A.F.F, on each side.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

**CRITERIA**

Floor: VCT - static dissipative  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**


- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

7.2.02, 8.2.02,  
11.2.02, 12.2.02

1,800 SF

**FLEX LAB / CLASSROOM**

SCALE: 3/32" = 1'-0"



**DESCRIPTION**

One 4' x 8' wall-mounted tackboard on a side wall near the entrance to the classroom. Two 4' x 8' wall-mounted marker boards.  
 One room with 12' built-in counter with sink with hot and cold water.  
 Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 Three power outlets with quadraplex outlets relating to data ports and duplex outlets spread equally on each wall.  
 Provide power,data connections and wall blocking at interactive flat panel locations.  
 One clock / intercom with call button 48" A.F.F

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: Yes

**CRITERIA**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**


- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

7.1.01, 8.1.01, 10.3.01,  
11.1.01, 12.1.01

600 SF

**RESOURCE CLASSROOM**

SCALE: 1/8" = 1'-0"



**DESCRIPTION**

Special learners classroom with 9 student capacity. Flexible seating; spacious with natural light. Connected to single user restroom and storage room. Provide one of the self-contained classrooms with a laundry room.  
 One 4' x 8' wall-mounted tackboard, on a side wall near the entrance to the classroom. Two 4' x 8' wall-mounted marker boards.  
 Data ports per current CCSD standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. Three power outlets with quadraplex outlets relating to data ports and duplex outlets spread equally on each wall.  
 Provide power, data connections and wall blocking at interactive flat panel locations.  
 One clock / intercom with call button 48" A.F.F.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: Yes

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**


- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- Ⓛ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- Ⓛ CLOCK/INTERCOM

SCALE: 1/8" = 1'-0"

7.2.04, 8.2.04, 11.2.04, 12.2.04

SELF-CONTAINED

900 SF



**DESCRIPTION**

General use individual stalls with common lavatory area. Access from hallway.  
 Water closet and lavatory to meet code.  
 One GFCI duplex outlet near lavatory. Liquid soap dispenser. Paper towel dispenser. Roll toilet paper dispenser. Sanitary napkin dispenser/disposal.  
 Shatterproof mirrors in lavatory area.  
 ADA accessible stall included.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

**FINISHES**

Floor: Resinous flooring  
 Walls: Ceramic tile/Paint  
 STC Rating: 51  
 Ceiling: Gypsum board  
 Height: 9'-0" min.  
 CAC Rating: 51  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- Ⓛ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- Ⓛ CLOCK/INTERCOM

SCALE: 1/4" = 1'-0"

2.2.05F, 2.2.05H,  
 7.2.05, 8.2.05, 10.2.07,  
 11.2.05, 12.2.05

STUDENT GENERAL USE RESTROOM


N/A

# 09 RESOURCE MATERIAL CENTER


# RESOURCE MATERIAL CENTER

|            |                                 |              |          |           |           |
|------------|---------------------------------|--------------|----------|-----------|-----------|
| <b>9.0</b> | <b>RESOURCE MATERIAL CENTER</b> | <b>8,070</b> | <b>1</b> | <b>30</b> | <b>25</b> |
|------------|---------------------------------|--------------|----------|-----------|-----------|

| 9.1 | Library Center                            | Qty. | Net Area | Total Net Area | Teaching | # Stud. | Capacity  |               | Functional |
|-----|---|------|----------|----------------|----------|---------|-----------|---------------|------------|
|     |   |      |          |                | #T.S.    |         | @ 100%    | Utilization % | Capacity   |
| .01 | Collaboration Space                       | 1    | 2,450    | 2,450          | 0        |         | -         |               | -          |
| .02 | Book Stacks                               | 1    | 2,150    | 2,150          | 0        |         | -         |               | -          |
| .03 | Small Group Rooms                         | 4    | 135      | 540            | 0        |         | -         |               | -          |
| .04 | Office                                    | 1    | 165      | 165            | 0        |         | -         |               | -          |
| .05 | Site-Based Technician                     | 1    | 600      | 600            | 0        |         | -         |               | -          |
| .06 | Library Conference/Career Counseling Room | 1    | 585      | 585            | 0        |         | -         |               | -          |
| .07 | Research/Career Classroom                 | 1    | 900      | 900            | 1        | 30      | 30        | 83%           | 25         |
| .08 | Library Storage/ Workroom                 | 1    | 680      | 680            | 0        |         | -         |               | -          |
|     |   |      |          | <b>8,070</b>   | <b>1</b> |         | <b>30</b> |               | <b>25</b>  |



# ROOM DATA SHEETS



## DESCRIPTION

Reading, study area for students.  
 Duplex outlets every 15 feet on walls. Four duplex outlets on back wall behind the charging desk.  
 If at least two columns are in the library, install isolated ground type quadraplex outlets on each side of the column coupled with a minimum of four data ports for student card catalog a inquires to library data providing there is clearance from other functions, including one telephone outlet.  
 Two ITV outlet. One CTV outlet.  
 Provide a second clock/intercom with call button (if room layout requires) to ensure a clock is seen from all points in the library. Sound isolation. Secure area.  
 Provide a display area adjacent to reading room viewable from hallway

## SERVICES

HVAC Room Noise Criteria (dBA): 40  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

## CRITERIA

Floor: Carpet tile  
 Walls: Paint  
 STC Rating: 48  
 Ceiling: ACT  
 Height: 15'-0" min.  
 CAC Rating: 40  
 Doors: -  
 STC Rating: -

Note: Use Acoustical Engineer for all spaces


## KEY

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

## 9.1.01 | COLLABORATION SPACE

SCALE: 1" = 10'-0"

2,450 SF



## DESCRIPTION

Central to classrooms and direct access from hallway by students.  
 Provide main double door entrance/exit to the corridor with a dual hallway book security system without the locking gates, with a Book Check unit - CFCI (If necessary, provide a wall for the book security system that should be full height, fire rated, wood framing not to interfere with system electronics and to prevent walking around the detection system.)  
 Provide a flush floor mounted duplex outlet with a dedicated circuit to support the detection system.  
 Provide a two-station charging desk with surge suppression, surfaced-mounted electrical outlets, and two data ports for a computer, printer, and time/date stamp.  
 One clock / intercom on wall behind the charging desk with call button.  
 Other required code exits need door alarms and signage indicating "Emergency Exit Only".  
 Visual supervision from the charging desk.  
 Three 4' x 8' wall-mounted tackboards, mount (1) near entrance.  
 Book stack area for 12,000+ volumes.

## SERVICES

HVAC Room Noise Criteria (dBA): 40  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

## CRITERIA

Floor: Carpet  
 Walls: Paint  
 STC Rating: 48  
 Ceiling: ACT / Gypsum board  
 Height: 20'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 48

Note: Use Acoustical Engineer for all spaces


## KEY

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

## 9.1.02 | BOOK STACKS

SCALE: 3/32" = 1'-0"

2,150 SF



**DESCRIPTION**

Group study room.  
 Direct access from main library.  
 Window for visual supervision from main library.  
 One 4' x 8' wall-mounted marker board.  
 Data ports and quadruplex outlets on two walls and power outlet on each remaining wall.  
 One clock / intercom near front door.

**CRITERIA**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51


Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM



**DESCRIPTION**

Librarian and aide/clerk.  
 Direct access from main library. Direct access to charging desk.  
 Window for visual supervision of main library.  
 One 4' x 4' wall-mounted tackboard.  
 Data ports per current CCSD Standard Premise wiring matrix with conduit for computer networking with cable back to the central computer rack. One quadruplex outlet on two walls related to potential desk locations and data ports. One duplex outlet on each remaining wall.  
 One clock / intercom near front door.

**CRITERIA**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

**KEY**

- ⊖ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊖ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

9.1.03 | SMALL GROUP ROOMS


SCALE: 1/4" = 1'-0"

135 SF

9.1.04 | OFFICE

SCALE: 3/8" = 1'-0"

165 SF



**DESCRIPTION**

Repair and maintenance of technological equipment. Relate access to the main library. Provide double door access. One 4' x 8' wall-mounted tackboard. Built-in work counter, 34" A.F.F., 30" deep, the length of one wall with sink on one end, hot/cold water, abovecounter 2100 series electrical plugmold with 20 amp receptacles 12" O.C., lockable cabinets, and undercounter lockable storage. Two data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. One duplex outlet on each non-counter wall. One clock / intercom with call button near entrance. Secure area.

**SERVICES**

HVAC Room Noise Criteria (dBA): -  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: Yes


**CRITERIA**

Floor: VCT  
 Walls: Paint  
 STC Rating: -  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: -

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM



**DESCRIPTION**

Direct access from main library. Seating for 30. One 4' x 8' wall-mounted tackboard. One 4' x 8' wall-mounted marker board. Two data ports related to quadraplex power per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack. Two additional duplex outlets on each wall. Provide power, data connections and backing at interactive flat panel locations. One ITV outlet. One CTV outlet. One clock / intercom with call button 48" A.F.F.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

**CRITERIA**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

9.1.05 | SITE BASED TECHNICIAN


600 SF

SCALE: 1/8" = 1'-0"

9.1.06 | LIBRARY CONF / CAREER COUNSELING ROOM

585 SF

SCALE: 1/8" = 1'-0"



**DESCRIPTION**

Direct access from main library.  
 One 4' x 8' wall-mounted tackboard near the entrance. Two 4' x 8' wall-mounted marker boards at the front of the room.(  
 30) Workstations.  
 Two quadraplex outlets and one additional duplex on each of three walls. Two duplex outlets and one quadraplex outlet on front wall.  
 One clock / intercom with call button 48" A.F.F.

**CRITERIA**



Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

**KEY**



**DESCRIPTION**

Direct access from with double door entry, no mullion.  
 Storage of library books and materials.  
 Built-in 8' counter with clean-up sink with hot and cold water with abovecounter plugmold outlets 12" O.C. Power connections not to be daisy chained.  
 Data port per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 One quadraplex outlet on two walls. One duplex outlet on each wall.  
 One clock / intercom with call button 48" A.F.F.

**CRITERIA**


Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: No

**KEY**



9.1.07 | RESEARCH/CAREER CLASSROOM

SCALE: 1/8" = 1'-0"

900 SF

9.1.08 | LIBRARY STORAGE/WORKROOM

SCALE: 3/16" = 1'-0"

680 SF



# 10 SCIENCE COMPLEX

# SCIENCE COMPLEX

|             |                        |  |  |               |           |            |            |
|-------------|------------------------|--|--|---------------|-----------|------------|------------|
| <b>10.0</b> | <b>SCIENCE COMPLEX</b> |  |  | <b>30,175</b> | <b>20</b> | <b>582</b> | <b>485</b> |
|-------------|------------------------|--|--|---------------|-----------|------------|------------|



| <b>10.1</b> | <b>Science Classrooms</b>               | Qty. | Net Area | Total Net Area | Teaching<br>#T.S. | # Stud. | Capacity<br>@ 100% | Utilization % | Functional<br>Capacity |
|-------------|---|------|----------|----------------|-------------------|---------|--------------------|---------------|------------------------|
| .01         | General Science Laboratory / Classrooms | 15   | 1,385    | 20,775         | 15                | 30      | 450                | 83%           | 375                    |
| .02         | Chemistry Laboratory / Classrooms       | 4    | 1,385    | 5,540          | 4                 | 30      | 120                | 83%           | 100                    |
|             |   |      |          | <b>26,315</b>  | <b>19</b>         |         | <b>570</b>         |               | <b>475</b>             |

| <b>10.2</b> | <b>Science Teacher Prep / Office / Storage</b> | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%   | Utilization % | Capacity |
|-------------|--|------|----------|----------------|----------|---------|----------|---------------|----------|
| .01         | Science Teacher Prep/ Office Area              | 1    | 850      | 850            | 0        |         | -        |               | -        |
|             | a. Science Teacher Prep Storage Room           | 1    | 185      | 185            | 0        |         | -        |               | -        |
|             | b. Physics / Chemistry Storage Room            | 1    | 165      | 165            | 0        |         | -        |               | -        |
|             | c. Science Text Book Storage Room              | 1    | 165      | 165            | 0        |         | -        |               | -        |
| .02         | Staff General Use Restroom                     | 1    |          | 0              | 0        |         | -        |               | -        |
| .03         | Custodial Storage                              | 1    | 55       | 55             | 0        |         | -        |               | -        |
| .04         | Electrical / Mechanical Room                   | 1    |          | 0              | 0        |         | -        |               | -        |
| .05         | T.R. Room                                      | 2    | 200      | 400            | 0        |         | -        |               | -        |
| .06         | Riser Room                                     | 1    |          | 0              | 0        |         | -        |               | -        |
| .07         | Student Restroom                               | 1    |          | 0              | 0        |         | -        |               | -        |
|             |  |      |          | <b>1,820</b>   | <b>0</b> |         | <b>0</b> |               | <b>0</b> |


| <b>10.3</b> | <b>Classrooms</b>   | Qty. | Net Area | Total Net Area | #T.S.    | # Stud. | @ 100%    | Utilization % | Capacity  |
|-------------|---------------------|------|----------|----------------|----------|---------|-----------|---------------|-----------|
| .01         | Resource Classroom  | 1    | 600      | 600            | 1        | 12      | 12        | 83%           | 10        |
| .02         | Journalism Workroom | 1    | 600      | 600            | 0        |         | -         |               | -         |
|             | a. Storage Room     | 1    | 120      | 120            | 0        |         | -         |               | -         |
| .03         | Yearbook Workroom   | 1    | 600      | 600            | 0        |         | -         |               | -         |
|             | a. Storage Room     | 1    | 120      | 120            | 0        |         | -         |               | -         |
|             |                     |      |          | <b>2,040</b>   | <b>1</b> |         | <b>12</b> |               | <b>10</b> |

## 10.0 SCIENCE COMPLEX

### 10.1 Science Classrooms




### 10.2 Science Teacher Prep / Office / Storage



### 10.3 Classrooms



# ROOM DATA SHEETS



## LAB REQUIREMENTS

Easy access to science teacher prep / office.  
 Appropriate ventilation, exhaust, eyewash, and safety shower.  
 One 4' x 8' wall-mounted tackboard near the entrance. Two 4' x 8' wall-mounted marker boards.  
 Provide wall blocking, power and data for interactive flat panel on teaching wall.  
 Instructor's lab/demo station with acid resistant work counter, electrical outlets, gas, sink with hot/cold water, and lockable undercounter storage. Shutoff for gas with automatic shutoff timer at fixed instructor's lab/demo station.  
 Area with walled perimeter (4) lab stations 36" high, 30" deep, with acid resistant work counter, (4) GFIC electrical duplex outlets and lockable undercounter material storage with adjustable shelving.  
 Lockable storage cabinets above between each sink. Lower one end of station for handicapped accessibility (34" A.F.F., 54" wide, and 24" deep) with no undercounter storage. Area for beaker storage. Area for lockable portable storage for 30 microscopes in each room.  
 Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 Quadraplex outlets related to data port locations. Electrical plugmold on non-lab station wall with outlets 18" on center.  
 Provide power, data connections and backing at interactive flat panel locations.  
 One clock / intercom with call button 48" A.F.F.

## FINISHES

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

## KEY

|  |                          |  |                |
|--|--------------------------|--|----------------|
|  | RECEPTACLE               |  | DATA           |
|  | QUAD RECEPTACLE          |  | TV OUTLET      |
|  | DATA/PHONE               |  | CLOCK/INTERCOM |
|  | FLOOR BOX (POWER & DATA) |  |                |


## SERVICES

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: Yes

SCALE: 3/32" = 1'-0"

## 10.1.01 | GENERAL SCIENCE LAB / CLASSROOMS

1,385 SF



## LAB REQUIREMENTS

Easy access to science teacher prep / office area.  
 Appropriate ventilation, exhaust, eyewash, and safety shower.  
 One 4' x 8' wall-mounted tackboard near the entrance.  
 Two 4' x 8' wall-mounted marker boards.  
 Provide wall blocking, power and data for interactive flat panel on teaching wall.  
 Instructor's lab/demo station with acid resistant work counter, electrical outlets, gas, sink with hot/cold water, and lockable undercounter storage. Shutoff for gas with automatic shutoff timer at fixed instructor's lab/demo station.  
 Area with walled perimeter (4) lab stations 36" high, 30" deep, with acid resistant work counter, (4) GFIC electrical duplex outlets, gas with (4) jets, (4) sinks with cold water, vacuum with (4) jets, and lockable undercounter material storage with adjustable shelving.  
 Lockable storage cabinets above and between each sink. Lower one end of station for handicapped accessibility (34" A.F.F., 54" wide, and 24" deep) with no undercounter storage.  
 One chemistry fume hood, CFCI.  
 Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 Quadraplex outlets related to data port locations. Electrical plugmold on non-lab station wall with outlets 18" O.C.  
 Provide power, data connections and backing at interactive flat panel locations.  
 One clock / intercom with call button 48" A.F.F.

## FINISHES

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

## KEY

|  |                          |  |                |
|--|--------------------------|--|----------------|
|  | RECEPTACLE               |  | DATA           |
|  | QUAD RECEPTACLE          |  | TV OUTLET      |
|  | DATA/PHONE               |  | CLOCK/INTERCOM |
|  | FLOOR BOX (POWER & DATA) |  |                |


## SERVICES

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: Yes

## 10.1.02 | CHEMISTRY LAB / CLASSROOMS

1,385 SF

SCALE: 3/32" = 1'-0"



**DESCRIPTION**

Teacher preparation area. Designate one wall to provide and embed a 6' x 5' display case visible to students in hallway 48" w x 88" h x 14" d with five adjustable shelves for student projects. One 4' x 8' wall-mounted tackboard near the entrance above the counter. One 10' built-in work counter with sink, hot/cold water, above counter electrical plugmold with outlets 24" O.C. and under counter storage. Electrical for copy machine. Six data ports per current CCSD standard premise wiring matrix with conduit for computer networking with cable on each wall back to the central computer rack. Quadplex outlets related to data ports and additional duplex outlets on each wall. Two floor mounted duplex outlets in each center half of room. One clock. One intercom with call button 48" A.F.F.

**SERVICES**

HVAC Room Noise Criteria (dBA): 45  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: Carpet  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 10'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51


Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

10.2.01 | SCIENCE TEACHER PREP / OFFICE AREA SCALE: 3/32" = 1'-0"

850 SF



**DESCRIPTION**

Direct access from science teacher prep / office. Ensure exhaust venting directly to roof from room. Ensure HVAC supply air to room. Provide emergency lighting for emergency egress. Storage of supplies, caustic materials, chemical items, flammable liquids, and animal specimen storage cabinets. Area for beaker storage. Area for lockable portable storage for 32 microscopes. Two duplex outlets on each wall.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51


Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

10.2.01A | SCIENCE TEACHER PREP STORAGE ROOM SCALE: 1/4" = 1'-0"

185 SF



**DESCRIPTION**

Direct access from science teacher prep / office.  
 Ensure exhaust venting directly to roof from room.  
 Ensure HVAC supply air to room.  
 Provide emergency lighting for emergency egress.  
 Storage of supplies, caustic materials, chemical items, flammable liquids, and animal specimen storage cabinets.  
 Area for beaker storage.  
 Area for lockable portable storage for 32 microscopes.  
 Two duplex outlets on each wall.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces


**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**10.2.01B, | SCIENCE STORAGE ROOM**  
**10.2.01C**

165 SF

SCALE: 1/4" = 1'-0"



**DESCRIPTION**

Custodial storage with mop sink with hot/cold water and mop rack, (include FRP on side walls that are drywall).  
 One duplex outlet.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: Yes  
 Power: 110v  
 Data: No  
 AV: No

**FINISHES**

Floor: Sealed concrete  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces



**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**10.2.03 | CUSTODIAL STORAGE**

55 SF

SCALE: 3/8" = 1'-0"



**DESCRIPTION**

Direct access to one generic classroom.  
 Work area for journalism students.  
 Two 4' x 8' wall-mounted tackboards.  
 One 4' x 8' wall-mounted marker boards.  
 One wall of tackable surface.  
 Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 Ten power outlets with one quadruplex related to each data port and additional duplex outlets on each wall.  
 One ITV outlet.  
 One clock / intercom with call button 48" A.F.F.

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with card reader  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: Yes

**DESCRIPTION**

Storage room for Journalism / Yearbook Workroom.  
 Storage of supplies and archive.  
 Ensure HVAC supply and return air.  
 Two duplex outlets.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: No  
 AV: No


**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with card reader  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▶ DATA
- ▶ TV OUTLET
- CLOCK/INTERCOM



**DESCRIPTION**

Direct access to one generic classroom.  
 Work area for yearbook students.  
 Two 4' x 8' wall-mounted tackboards.  
 One 4' x 8' wall-mounted marker board.  
 One wall of tackable surface.  
 Data ports per current CCSD Standard premise wiring matrix with conduit for computer networking with cable back to the central computer rack.  
 Ten power outlets with one quadruplex outlet related to each data port and additional duplex outlets on each wall.  
 One clock / intercom with call button 48" A.F.F.

**SERVICES**

HVAC Room Noise Criteria (dBA): 35  
 Plumbing: No  
 Power: 110v  
 Data: Yes  
 AV: No

**FINISHES**

Floor: VCT  
 Walls: Paint  
 STC Rating: 51  
 Ceiling: ACT  
 Height: 9'-0" min.  
 CAC Rating: 40  
 Doors: Solid core wood with vision lite  
 STC Rating: 51

Note: Use Acoustical Engineer for all spaces

**KEY**

- ⊕ RECEPTACLE
- ⊕ QUAD RECEPTACLE
- ▶ DATA/PHONE
- ⊕ FLOOR BOX (POWER & DATA)
- ▷ DATA
- ▶ TV OUTLET
- ▭ CLOCK/INTERCOM

**10.3.03 | YEARBOOK WORKROOM**

SCALE: 1/8" = 1'-0"

600 SF